

CERTIFICATION OF APPROVAL

CONDITION MONITORING ANALYSIS ON POWER TRANSFORMER AT PETRONAS GAS BERHAD (PGB) MAIN SUBSTATION

by

Noor Hertiana Binti Hasbullah

A project dissertation submitted to the
Electrical and Electronics Engineering Programme
Universiti Teknologi PETRONAS
in partial fulfillment of the requirement for the
BACHELOR OF ENGINEERING (Hons)
(ELECTRICAL AND ELECTRONICS ENGINEERING)

Approved by,

(Ir. Mohd Faris Bin Abdullah)

Project Supervisor

UNIVERSITI TEKNOLOGI PETRONAS

TRONOH, PERAK

December 2009

CERTIFICATION OF ORIGINALITY

This is to certify that I am responsible for the work submitted in this project, that the original work is my own except as specified in the references and acknowledgements, and that the original work contained herein have not been undertaken or done by unspecified sources or persons.

NOOR HERTIANA HASBULLAH

ABSTRACT

This report is the final report on study done and summary of the chosen topic, which is **Condition Monitoring Analysis on Power Transformer at PETRONAS Gas Berhad (PGB) Main Substation**. The objective of the project is to analyze the current state of condition of the power transformer using the condition monitoring data and to propose recommendations to mitigate the risk of failure. Power Transformer at Gas Processing Plant, PETRONAS Gas Berhad main substation had been in service for a long time, approximately 10 years. Since power transformer is a critical component of the power transmission and distribution system, the failure risk is of prime importance. The scope of study for this project are literature review on condition monitoring method on power transformer such as partial discharge, tan delta, oil analysis, sweep frequency response analysis (SFRA), ratio test analysis, dielectric test etc. Then, proceed with the analysis of the current state condition of the power transformer by studying the data trending pattern as well as acceptance criteria level of the condition monitoring data available from plant. Lastly, if abnormalities are found, then remedial action will be proposed to improve the condition of the power transformer.

ACKNOWLEDGEMENT

In the Name of Allah, the Most Beneficent the Most Merciful;

The author would like to take this opportunity here to express deepest gratitude to the following personnel for their contributions, supports, ideas and etc for the successful completion of this final year project.

- Mr. Ir. Mohd Faris Abdullah, Project Supervisor, Electrical & Electronic Engineering Senior lecturer.
- Mr. Zaidi, Executives, PETRONAS Gas Berhad, Kerteh.
- Mr. Rusli Jusoh, Branch Manager, ASAGA Corporation, Kerteh Division.
- Mr. Zulfadhlly Zardi, Lab Manager, Transformer Oil Lab, TNB Research Sdn. Bhd.
- Mr. Michel Duval, inventor of Duval Triangle Method for analysing DGA.
- Mrs. Siti Hawa Haji Mohd Tahir, Lab Technologist, Electrical & Electronic Engineering Department, Universiti Teknologi PETRONAS.
- All supporting person who are directly or indirectly involve in contribution of completing this project.

Thank You.

TABLE OF CONTENT

| | | | |
|--|---|------------|----|
| ABSTRACT | | iv | |
| ACKNOWLEDGEMENT | | v | |
| LIST OF FIGURES | | ix | |
| LIST OF TABLES | | x | |
| ABBREVIATIONS AND NOMENCLATURES | | xii | |
| CHAPTER 1 INTRODUCTION | | 1 | |
| 1.1 | Background of Study | | 1 |
| 1.2 | Problem Statement | | 2 |
| 1.3 | Objectives & Scope of Study | | 2 |
| 1.3.1 | <i>Objectives</i> | | 2 |
| 1.3.2 | <i>Scope of Study</i> | | 2 |
| CHAPTER 2 LITERATURE REVIEW | | 3 | |
| 2.1 | Condition Monitoring & Preventive Maintenance | | 3 |
| 2.2 | PETRONAS Technical Standards | | 5 |
| 2.3 | Oil Analysis Test | | 6 |
| 2.3.1 | <i>Neutralization Number</i> | | 6 |
| 2.3.2 | <i>Moisture Content</i> | | 6 |
| 2.3.3 | <i>Oil Dielectric Breakdown Strength</i> | | 7 |
| 2.3.4 | <i>Interfacial Tension (IFT)</i> | | 7 |
| 2.3.5 | <i>Dielectric Dissipation Factor (DDF)</i> | | 8 |
| 2.4 | Dissolved Gas Analysis (DGA) | | 8 |
| 2.4.1 | <i>Roger Ratio Method</i> | | 10 |
| 2.4.2 | <i>Duval Triangle Method</i> | | 11 |
| 2.5 | Furan Analysis | | 15 |

| | | |
|---|---|-----------|
| 2.6 | Ratio & Insulation Resistance Test | 15 |
| 2.7 | Sweep Frequency Response Analysis (SFRA) Test | 16 |
| 2.8 | Tan Delta Test | 16 |
| 2.9 | Partial Discharge Test | 17 |
| CHAPTER 3 METHODOLOGY..... | | 18 |
| 3.1 | Procedure Identification of the Project | 18 |
| CHAPTER 4 RESULTS & DISCUSSION | | 19 |
| 4.1 | Results and Discussion for DGA Analysis | 19 |
| 4.1.1 | <i>Result of analysis for TR5-AB-01 (132kV/33kV)....</i> | 19 |
| 4.1.2 | <i>Result of analysis for TR5-AB-02 (132kV/33kV)....</i> | 21 |
| 4.1.3 | <i>Result of analysis for TRD-BD-01 (33kV/6.6kV) ...</i> | 23 |
| 4.1.4 | <i>Result of analysis for TR5-BD-01 (33kV/6.6kV)</i> | 25 |
| 4.1.5 | <i>Result of analysis for TR5-BD-02 (33kV/6.6kV)</i> | 27 |
| 4.1.6 | <i>Result of analysis for TR6-BD-01 (33kV/6.6kV)</i> | 29 |
| 4.1.7 | <i>Result of analysis for TR6-BD-02 (33kV/6.6kV)</i> | 31 |
| 4.1.8 | <i>Result of analysis for TR5-DE-62 (6.6kV/415V)</i> | 33 |
| 4.1.9 | <i>Result of analysis for TR5-DE-52 (6.6kV/415V)</i> | 35 |
| 4.1.10 | <i>Result of analysis for TR5-DE-61 (6.6kV/415V)</i> | 37 |
| 4.1.11 | <i>Result of analysis for TR5-DE-51 (6.6kV/415V)</i> | 38 |
| 4.2 | Result and Discussion for Oil Quality Testing | 40 |
| 4.3 | Result and Discussion for Furan Analysis | 43 |
| CHAPTER 5 CONCLUSIONS & RECOMMENDATION | | 44 |
| 5.1 | Conclusion | 44 |
| 5.2 | Recommendation | 46 |
| 5.2.1 | <i>Procedure to be taken for thermal faults</i> | 46 |
| 5.2.2 | <i>Procedure for arching or discharge fault</i> | 47 |
| 5.2.3 | <i>Improvement the condition monitoring at PGB</i> | 49 |
| 5.2.4 | <i>Recommendation to this project</i> | 49 |

| | | |
|---------------------------------------|-------|-----------|
| REFERENCES | | 50 |
| APPENDIX | | 52 |
| APPENDIX A DGA (TR5-AB-01) 132kV/33kV | | 53 |
| APPENDIX B DGA (TR5-AB-02) 132kV/33kV | | 54 |
| APPENDIX C DGA (TRD-BD-01) 33kV/6.6kV | | 55 |
| APPENDIX D DGA (TR5-BD-01) 33kV/6.6kV | | 56 |
| APPENDIX E DGA (TR5-BD-02) 33kV/6.6kV | | 57 |
| APPENDIX F DGA (TR6-BD-01) 33kV/6.6kV | | 58 |
| APPENDIX G DGA (TR6-BD-02) 33kV/6.6kV | | 59 |
| APPENDIX H DGA (TR5-DE-62) 6.6kV/415V | | 60 |
| APPENDIX I DGA (TR5-DE-52) 6.6kV/415V | | 60 |
| APPENDIX J DGA (TR5-DE-61) 6.6kV/415V | | 61 |
| APPENDIX K DGA (TR5-DE-51) 6.6kV/415V | | 61 |
| APPENDIX L DUVAL TRIANGLE METHOD | | 62 |
| APPENDIX M PROJECT'S GANTT CHART | | 63 |

LIST OF FIGURES

| | |
|---|----|
| Figure 1: Maintenance plan of work for plant operation of PGB | 5 |
| Figure 2: Figure above shows the Duval Triangle for analyzing. [15] | 12 |
| Figure 3: Perfect capacitor angle | 16 |
| Figure 4: The angle of delta | 16 |
| Figure 5: Flow chart of project | 18 |
| Figure 6: Strength of a transformer [6] | 44 |
| Figure 7: Flow diagram of thermal fault. | 46 |
| Figure 8: Flow diagram of arching or partial discharge | 48 |

LIST OF TABLES

| | |
|---|----|
| Table 1: Gas Ratio Codes [14] | 9 |
| Table 2: Roger's Ratio Codes [14] | 10 |
| Table 3: Classification based on Roger's Ratio Codes [14] | 10 |
| Table 4: Examples of faults detectable by DGA [15] | 13 |
| Table 5: DGA Testing Data for TR5-AB-01 | 18 |
| Table 6: Analysis (Referring to APPENDIX A) | 19 |
| Table 7: Summation of calculation for A, B, C, S, X, Y & Z for two years | 19 |
| Table 8: DGA Testing Data for TR5-AB-02 | 20 |
| Table 9: Analysis (Referring to APPENDIX B) | 20 |
| Table 10: Summation of calculation for A, B, C, S, X, Y & Z for two years | 21 |
| Table 11: DGA Testing Data for TRD-BD-01 | 21 |
| Table 12: Analysis (Referring to APPENDIX C) | 22 |
| Table 13: Summation of calculation for A, B, C, S, X, Y & Z for two years | 22 |
| Table 14: DGA Testing Data for TR5-BD-01 | 23 |
| Table 15: Analysis (Referring to APPENDIX D) | 24 |
| Table 16: Summation of calculation for A, B, C, S, X, Y & Z for two years | 24 |
| Table 17: DGA Testing Data for TR5-BD-02 | 25 |
| Table 18: Analysis (Referring to APPENDIX E) | 26 |
| Table 19: Summation of calculation for A, B, C, S, X, Y & Z for two years | 26 |
| Table 20: DGA Testing Data for TR6-BD-01 | 27 |
| Table 21: Analysis (Referring to APPENDIX F) | 28 |
| Table 22: Summation of calculation for A, B, C, S, X, Y & Z for two years | 28 |
| Table 23: DGA Testing Data for TR6-BD-02 | 29 |

| | |
|---|----|
| Table 24: Analysis (Referring to APPENDIX G) | 30 |
| Table 25: Summation of calculation for A, B, C, S, X, Y & Z for two years | 30 |
| Table 26: DGA Testing Data for TR5-DE-62 | 31 |
| Table 27: Analysis (Referring to APPENDIX H) | 32 |
| Table 28: Summation of calculation for A, B, C, S, X, Y & Z for one year | 32 |
| Table 29: DGA Testing Data for TR5-DE-52 | 33 |
| Table 30: Analysis (Referring to APPENDIX I) | 34 |
| Table 31: Summation of calculation for A, B, C, S, X, Y & Z for one year | 34 |
| Table 32: DGA Testing Data for TR5-DE-61 | 35 |
| Table 33: Analysis (Referring to APPENDIX J) | 35 |
| Table 34: Summation of calculation for A, B, C, S, X, Y & Z for one year | 36 |
| Table 35: DGA Testing Data for TR5-DE-51 | 36 |
| Table 37: Analysis (Referring to APPENDIX K) | 37 |
| Table 38: Summation of calculation for A, B, C, S, X, Y & Z for one year | 37 |
| Table 39: Oil Quality Testing Data for TR5-AB-02 | 38 |
| Table 40: Oil Quality Testing Data for TR5-AB-01 | 38 |
| Table 41: Oil Quality Testing Data for TRD-BD-01 | 39 |
| Table 42: Oil Quality Testing Data for TR5-BD-01 | 39 |
| Table 43: Oil Quality Testing Data for TR5-BD-02 | 39 |
| Table 44: Oil Quality Testing Data for TR6-BD-01 | 40 |
| Table 45: Oil Quality Testing Data for TR6-BD-02 | 40 |
| Table 46: Furan Compound Data for TR6-BD-01 | 41 |
| Table 47: Furan Compound Data for TR6-BD-02 | 41 |

ABBREVIATIONS AND NOMENCLATURES

| | |
|------|--|
| PGB | PETRONAS Gas Berhad |
| IEC | International Electro technical Commission |
| PTS | PETRONAS Technical Standard |
| SFRA | Sweep Frequency Response Analysis |
| IR | Insulation Resistance |
| DDF | Dielectric Dissipation Factor |
| IFT | Interfacial Tension |
| OQL | Oil Quality Index |
| DGA | Dissolved Gas Analysis |
| PD | Partial Discharge |
| OIP | Oil Impregnated Cellulose Paper |
| OLTC | On Load Tap Changer |