

**POWER SYSTEM DESIGN AND MODELLING  
USING ERACS**

By

RUSDEE AZEEM BIN MOHAMAD RUSLI

**FINAL PROJECT REPORT**

Submitted to the Electrical & Electronics Engineering Programme  
in Partial Fulfillment of the Requirements  
for the Degree  
Bachelor of Engineering (Hons)  
(Electrical & Electronics Engineering)

Universiti Teknologi Petronas  
Bandar Seri Iskandar  
31750 Tronoh  
Perak Darul Ridzuan

© Copyright 2009  
by  
Rusdee Azeem Mohamad Rusli, 2009

## **CERTIFICATION OF APPROVAL**


### **POWER SYSTEM DESIGN AND MODELLING USING ERACS**

by

Rusdee Azeem B Mohamad Rusli

A project dissertation submitted to the  
Electrical & Electronics Engineering Programme  
Universiti Teknologi PETRONAS  
in partial fulfilment of the requirement for the  
Bachelor of Engineering (Hons)  
(Electrical & Electronics Engineering)

Approved:

  
Dr. Taj Mohammad Baloch  
Senior Lecturer  
04.66 (09) Electrical and Electronics Engineering,  
New Academic Block No 22  
Universiti Teknologi PETRONAS  
Bandar Seri Iskandar  
31750 Tronoh, Perak Darul Ridzuan, MALAYSIA  
Dr Taj Mohammad Baloch  
Project Supervisor

**UNIVERSITI TEKNOLOGI PETRONAS  
TRONOH, PERAK**

June 2009

## **CERTIFICATION OF ORIGINALITY**

This is to certify that I am responsible for the work submitted in this project, that the original work is my own except as specified in the references and acknowledgements, and the original work contained herein have not been undertaken or done by unspecified sources or person.



---

KUSDEE AZEEM MOHAMAD RUSLI

## **ABSTRACT**

Power system analysis means verifying the adequacy of the power distribution system and its components. It also studies the data analysis and power system as the basic improving system performance and power quality, reducing operating costs, and providing a reliable supply of power system during operation. As for the result, the objective of this project was to determine the performance of an electrical power system. Several testing technique such as Short Circuit Study and Load Flow Study was performed. In order to make the system analysis more reliable, the studies will be conducted by using special power system analysis tools software, ERACS. By using this software, the design and modeling a power system was carried out in order to determine system operate based on different scenarios. This technique was applied not only in new system but also used in the analysis of existing power system that study the effect of change or extension in the system.

## **ACKNOLEDGEMENTS**

I would like to extend my gratitude to the entire person who has helped me throughout out my final year project. Special thanks to Allah s.w.t for the guidance, strength and for being with me every inch of my step. Greatest appreciation and gratitude to my supervisor, Dr Taj Mohammad Baloch for his supervision, commitment and professionalism.

A special acknowledgement and appreciation goes to,

- My parents and family, Mohamad Rusli Bin Omar and Robitah Bt Ambri.
- Mr Ir Mohd Fariz, Lecturer Electrical and Electronic Engineering for his guidance and advice.
- Ms Hafizah, TNB Distribution Engineer for her support.
- All technician of Electrical Engineering Department
- Colleagues for cheering me up when days are dark.

Last but not least, I would like also to thanks to the people who had helped me directly or indirectly throughout my final year project. I would like to thank to the University for give us the opportunity to show our full potential in order towards well rounded students.

## **TABLE OF CONTENTS**

<b>ABSTRACT.....</b>	<b>v</b>
----------------------	----------

### **CHAPTER 1 : INTRODUCTION**

1.1	Background of study.....	1
1.2	Problem Statement.....	2
1.3	Objective.....	2

### **CHAPTER 2 : LITERATURE REVIEW**

2.1	Power System Analysis.....	3
2.1.1	Generation.....	3
2.1.2	Transmission.....	4
2.1.3	Distribution.....	6
2.2	Malaysia Electricity Supply System.....	6
2.3	Load Flow Study.....	8
2.4	Short Circuit Study.....	10
2.5	Transformer.....	12
2.6	Induction Motor.....	14
2.7	Synchronous Generator.....	15
2.8	Quality of Supply.....	16

### **CHAPTER 3 : METHODOLOGY**

3.1	Analysis Technique.....	17
3.2	Procedure Identification.....	18
3.3	Grant Chard.....	20

### **CHAPTER 4 : RESULT AND FINDINGS**

4.1	Design Criteria.....	21
4.2	Load Flow Study.....	27
4.2.1	Cost Evaluation .....	31
4.3	Short Circuit Study.....	34

### **CHAPTER 5 : CONCLUSION & RECOMMENDATION.....39**

<b>APPENDICES.....</b>	<b>41</b>
Appendix A : Power System Component.....	42
Appendix B : Case 1.....	55
Appendix C : Case 2.....	67
Appendix D : Case 3.....	79
Appendix E : Case 4.....	91

## **LIST OF FIGURES**

- Figure 1 Power System Components
- Figure 2 Short Transmission Line
- Figure 3 TNB Power Distribution System
- Figure 4 Single Phase to Earth
- Figure 5 Phase to Phase Fault
- Figure 6 Two Phase to Earth Fault
- Figure 7 Equivalent Circuit
- Figure 8 Equivalent Circuit Induction Motor
- Figure 9 Equivalent Circuit Synchronous Generator
- Figure 10 Project process
- Figure 11 Normal Condition
- Figure 12 Input for Grid Infeed
- Figure 13 Input for Busbar Data
- Figure 14 Input for Transformer Data
- Figure 15 Input for Induction Motor Data
- Figure 16 Input for Shunt Data
- Figure 17 Busbar BB11-11kV OPEN
- Figure 18 Busbar BB11-11kV and BB13-11kV OPEN
- Figure 19 Busbar BB11-11kV , BB13-11kV and BB7-11kV OPEN
- Figure 20 Short Circuit Study Setup Menu

## **LIST OF TABLE**

- Table 1: Load Flow Result
- Table 2 : Load Flow Summary Result
- Table 3: Total Amount Of Losses
- Table 4: Three Phase Short Circuit Study on Busbar 415V
- Table 5: Three Phase Short Circuit Study on Busbar 11kV
- Table 6: Three Phase Short Circuit Study on Busbar 132kV
- Table 7: Short Circuit Level for various Voltage Level
- Table 8 : Short Circuit at Busbar BB4-11kV
- Table 9 : Short Circuit at Busbar BB6-11kV
- Table 10 : Short Circuit at Busbar BB14-11kV

## **CHAPTER 1**

### **INTRODUCTION**

#### **1.1 Background of study**

Power system analysis basically consists of three main categories that need to focus such as power generation, transmission, and distribution. These three categories are also known as power system components. The ability to design and model a power system analysis using certain software is important nowdays in order to determine the best operation and expansion of the power system. It is also necessary to carry out study to be able to design and model a power system with minimum interruptions.

In order to get a good system, there are several factors that need to be consider when performing power system analysis such as load flow study. The power system load flow study was performed in order to determine the steady-state operation of an electric system. It also calculates the voltage drop on each feeder, the voltage at each bus, and also the power flow in all branch and feeder circuits. As for a result, it also calculates the losses in each branch and total power system losses.

A short circuit testing technique was also performed where by to determine the maximum current that will present during disturbance. Short circuit currents are computed for each relay and circuit breaker location and for various system-operating conditions such as lines or generating units out of services, in order to determine minimum and maximum fault current.

## **1.2 Problem Statement**

The electric utility is the largest and most complex industry in the world today. The electrical engineers encounter challenging problems in designing future power system to deliver increasing amounts of electrical energy in a safe, clean, and economical manner. Many calculations need to be done and for certain cases, the manual calculation makes power system analysis tedious and waste of time. In order to assist the engineer, digital computers and highly developed computer software programs are used. During this project, ERACS software was used in order to design and model a power system that would perform short circuit and load flow study testing techniques.

## **1.3 Objective**

The objectives of the project are as follows:

- Investigate and understand the power system generation, transmission and distribution in Malaysia.
- To design and develop a prototype of the distribution real system using proper software, ERACS.
- To perform a certain performance testing techniques such as short circuits and load flow study.

## **CHAPTER 2**

### **LITERITURE REVIEW**

#### **2.1 Power system analysis**

Power system analysis is basically divided into three major components which was generation, transmission and distribution. All of these three stage have their different voltage level and task. A good knowledge about power system components is needed in order to model and design a certain power system.



**Figure 1: Power System Components**

##### **2.1.1 Generation**

Electric generation is basically the process of converting a non-electrical energy to electrical energy. This is the first steps in order to delivery the electricity to the consumer. The power generation in Malaysia is derived from a combination of oil fired thermal, hydro, gas turbine, diesel, and combined cycle plants. With the exception of the small diesel and mini hydro plants the rest are interconnect via a high voltage transmission line which is known as National Grid Network. Beside of this, there are also many and new technologies to generate the electricity such as solar photovoltaics.


## **2.1.2 Transmission**

The purpose of the transmission network is to transfer electric energy from generating units at various locations to the distribution system which ultimately supplied load. In other words, it is the movement of energy from its generation to a location where it is applied to performing a useful work. Transmission voltage is alternating that can be easily stepped up by a transformer in order to minimize resistive loss in the conductors used to transmit power over great distance.

In United state, American National Standard Institute (ANSI) has set the standard of transmission voltages that have to follow. The transmission line that operating more than 60kV are standardized at 69kV, 115kV, 138kV, 161kV, 230kV, 345kV, 500kV and 765kV line to line. Transmission lines above 230kV are usually referred to extra-high voltage (EHV). EHV was basically terminated at the station known as substation or called high voltage substation, receiving substations, or primary substation. Some of the substation functions are act as a switching circuit in and out of service or known as switching stations. The voltage is then step down to a value that is needed at the primary substations for the next distribution to the different loads.

A sub-transmission is referred as the portion of the transmission system that connects the high voltage substation through step-down transformer to the distribution system. The voltage range of sub-transmission is about 60 to 138kV and some of the industrial may be served from this sub-transmission. As for the result, capacitor banks and reactor banks are usually installed in the substations for maintaining the transmission line voltage.

The model of the transmission line and busbar can be represented by using short transmission line that is shown below:



**Figure 2: Short Transmission Line**

From the above, the short line model can be as below;

$$\begin{aligned} Z &= (r + j\omega L)l \\ &= R + jX \end{aligned}$$

$V_s$  and  $I_s$  are the phase voltage and current at the sending end of the line, and  $V_r$  and  $I_r$  are the phase voltage and current at the receiving end of the line. There are two types that needed to know such as the voltage regulation ( $V_r$ ) and transmission line efficiency ( $\eta$ ). Voltage regulation is the percentage change in voltage at the receiving end of the line in going from no-load to full-load.

$$\%VR = \frac{[V_{R(NL)}] - [V_{R(FL)}]}{V_{R(FL)}}$$

Where,

$$V_{R(NL)} = V_s$$

The transmission line efficiency is given by :

$$\eta = \frac{P_{R(3\phi)}}{P_{S(3\phi)}}$$

$P_{R(3\phi)}$  and  $P_{S(3\phi)}$  = total real power at receiving end and sending end of line

### **2.1.3 Distribution**


A distribution system connects the distribution substation to the customer service entrance equipment. It involves a medium voltage(less than 50kV) power lines, electrical substation and pole mounted transformer, low-voltage (less 1000V) distribution wiring and sometimes electricity meters. The secondary distribution networks reduce the voltage for commercial and residential consumers (240V). The length of lines and cable are not exceeding a few hundred feet which is then deliver to the consumers.

Distribution power nowadays is carried out by 2 ways which are overhead and underground. The growth of the underground has been extremely rapid and as much as 70 percent new residential constructions are served underground.

### **2.2 Malaysia Electricity Supply System**

Malaysia electricity supply system is known as National Grid Network. Its is the primary transmission network that links from the generation, transmission, distribution and consumption in Malaysia. Tenaga Nasional Berhad( TNB) an electricity utility company in Peninsular Malaysia promotes generation, transmission and distribution of electrical energy with a view to encourage the economic development of states of Peninsular Malaysia.

As transmission and distribution system is highly exposed to the environment, external protections are provided on every part and piece of equipment to avoid being damaged during fault. The major fault rate in Peninsular Malaysia is due to lightening.



**Figure 3: TNB basic power distribution system**

## **2.3 Load Flow Study**

Power flow study or load flow study is referred to a valuable system which involves multiple loads. The reason that this study will be conduct through out the project is in order to analysis the system capability to adequate supply the connected load. Load flow studies are performed in order to determine the steady-state operation of an electric power system. Its will calculate the voltage drop on each feeder, power flow at all branch, voltage at each bus and feeder circuits. The other type, such as the losses in each branch and the total system loses are also calculated.

Like all system studies, it determines if system voltages remain within specified limits under various contingency conditions, and whether equipment such as transformers and conductors are overloaded. The reason that we conduct this performing testing technique is to identify the need for additional generation, capacitive, or inductive VAR support, or the placement of capacitors in order to maintain system voltages within specified limits. Power flow is the backbone of power system analysis and design which will be use full for operation, planning, economic scheduling and exchange power between utilities. Theoretically, there are two common ways to solve nonlinear algebraic equation which is Gauss-Seidel and Newton-Raphson methods.

### **Gauss-Seidel Method**

$$V_i^{(k+1)} = \frac{\frac{P_{isch} - jQ_{sch}}{V_i^{(k)}} + \sum_{j=1}^n y_{ij} V_j^{(k)}}{\sum_{j=0}^n y_{ij}}$$

### **Newton-Raphson Method**

This method is mathematically superior to the Gauss-Seidel method. Newton-Raphson are used for a large power system because more efficient and practical.

Elements of Jacobian matrix are partial derivative and can be written below:

$$\begin{bmatrix} \Delta P \\ \Delta Q \end{bmatrix} = \begin{bmatrix} J_1 J_2 \\ J_3 J_4 \end{bmatrix} \begin{bmatrix} \Delta \delta \\ \Delta [V] \end{bmatrix}$$

The diagonal and off-diagonal elements of J1 are

$$\frac{\partial P_i}{\partial \delta i} = \sum_{j \neq i} [V_i][V_j][Y_{ij}] \sin(\theta_{ij} - \delta i + \delta j)$$

$$\frac{\partial P_i}{\partial \delta i} = -[V_i][V_j][Y_{ij}] \sin(\theta_{ij} - \delta i + \delta j), j \neq i$$

The diagonal and off-diagonal elements of J2 are

$$\frac{\partial P_i}{\partial [V_i]} = 2[V_i][Y_{ii}] \cos \theta_{ii} + \sum_{j \neq i} [V_j][Y_{ij}] \cos(\theta_{ij} - \delta i + \delta j)$$

$$\frac{\partial P_i}{\partial [V_i]} = [V_i][Y_{ij}] \cos(\theta_{ij} - \delta i + \delta j)$$

The diagonal and off-diagonal elements of J3 are

$$\frac{\partial Q_i}{\partial \delta i} = \sum_{j \neq i} [V_i][V_j][Y_{ij}] \cos(\theta_{ij} - \delta i + \delta j)$$

$$\frac{\partial Q_i}{\partial \delta i} = -[V_i][V_j][Y_{ij}] \cos(\theta_{ij} - \delta i + \delta j), j \neq i$$

The diagonal and off-diagonal elements of J4 are

$$\frac{\partial Q_i}{\partial [V_i]} = -2[V_i][Y_{ii}] \sin \theta_{ii} - \sum_{j \neq i} [V_j][Y_{ij}] \sin(\theta_{ij} - \delta i + \delta j)$$

$$\frac{\partial Q_i}{\partial [V_i]} = -[V_i][Y_{ij}] \sin(\theta_{ij} - \delta i + \delta j)$$

## 2.4 Short Circuit Study


Short circuit study is where by the study of abnormal condition that involve in one or more phases unintentionally coming contact with the ground or each other. The connection of the positive, negative and zero sequence networks for each of the following short circuits faults is described as below:

- a) Single Phase to Earth
- b) Phase to Phase
- c) Two Phase to Earth

As expansion of the power system nowadays, loads maybe move or larger ones are added, which will cause increased levels of available short circuit currents.

### A) Single Phase to Earth


The single phase to earth fault, is assume to be between phase A and earth, this can shown in the figure 3 with the connection of the sequence networks.



**Figure 4: Single Phase to Earth**

## B) Phase to phase fault


For the phase to phase fault, the short circuit is assume to be between phase B and phase C, this is shown as figure above:



**Figure 5: Phase to Phase Fault**

## C) Two phase to earth fault

In two phase to earth fault, its assume to be between phase B, phase C and earth this is shown in figure above:



**Figure 6: Two phase to earth fault**

## 2.5 Transformer

A transformer is a device that changes ac electric power at one voltage level to ac electric power at another voltage level through the action of a magnetic field. It consists of two or more coils of wire wrapped around a common ferromagnetic core. These coils are not directly connected. The only connection between the coils is the common magnetic flux present within the core [2].

### Transformer Configuration

Power transformer has one or two type of cores. One type of cores consists of very simple rectangular laminated steel with transformer winding wrapped around two sides of rectangle. The primary and secondary winding is wrapped one on top of the other because of below reason:

- A) Simplified problem insulating HV winding from core.
- B) Less leakage

Power transformer has a variety of names that used in power system nowdays depending on the voltage itself. A unit transformer is a transformer that coming from the generator and was used to step-up the voltage to transmission level (110kV above). At the end of the transmission line, the voltage is then step-down and this transformer are called *substation transformer* (132kV to 11kV). The last transformer that takes the lower voltage or LV(415V and 240 V) are called distribution transformer.




Figure 7: Equivalent Circuit

## Ideal Transformer

Consider the transformer was an ideal transformer. Which is the transformer having a lossless device at input winding and output winding. The relation ship between input and output voltage, current input and output are shown below

$$\frac{V_{P(t)}}{V_{S(t)}} = \frac{N_P}{N_S} = \frac{i_{S(t)}}{i_{P(t)}} = a \quad a \text{ is define as turn ratio}$$

VP(t)= Voltage at primary side

VS(t)= Voltage at secondary side

NP=turns of wire at primary side

NS= turns of wire at secondary side

In an ideal transformer, the power supply by the primary circuit is given by

$$P_{in} = V_P I_P \cos \theta_P \quad \theta_P = \text{angle between primary voltage and current}$$

At the secondary transformer, the power is given by

$$P_{out} = V_S I_S \cos \theta_S \quad \theta_S = \text{angle between secondary voltage and current}$$

Relationship between input and output power is the output power is equal to input power and given by

$$P_{out} = V_P I_P \cos \theta_P = P_{in}$$

The same relationship also apply to the reactive power Q and apparent power S,

$$Q_{in} = V_P I_P \sin \theta = V_S I_S \sin \theta = Q_{out} \quad \text{and}$$

$$S_{in} = V_P I_P = V_S I_S = S_{out}$$

## 2.6 Induction Motor

Induction machine is a machine that has amortisseur windings and the rotor voltage is induced in rotor windings rather than being physically connected wires. The best describe of induction machine is that it doesn't have dc field current connected to it in order to run the machine. Industrial nowdays used many three phase induction in a standard workhorse for high power application. The speed of the Magnetic field rotation is given by

$$N_{sync} = \frac{120f_e}{P}$$

$f_e$  = system frequency  
 $P$  = number of poles

Voltage in rotor depends on speed of the rotor relative to the magnetic fields. There are 2 term to define the relative motion of rotor and magnetic field which is slip speed and slip. The slip speed and slip equation is given by

$$\Omega_{slip} = \Omega_{sync} - \Omega_m$$

$$s = \frac{\Omega_{slip}}{\Omega_{sync}} \times 100\%$$

The rotor frequency  $f_r$ , torque  $T$ , and power  $P$  is ;

$$f_r = sf_e$$

$$T = \frac{P}{W_m} = \frac{60P}{2pn_m}$$





Figure 8: Equivalent Circuit Induction Motor

## 2.7 Synchronous Generator

Synchronous generator is basically a synchronous machine that used to convert mechanical power to electrical power. Dc power supply is used on the rotor winding that will induce a magnetic field in rotor. The rotor itself will turn by a prime mover that will also produce a rotating magnetic field that will produce 3 phase voltage. There are 2 winding which is field winding (rotor) and armature (stator) winding. Below is basically the equivalent circuit of synchronous generator:



**Figure 9: Equivalent Circuit Synchronous Generator**

The rotation of the magnetic field in this machine is related to the stator electrical frequency which is:

$$f_e = \frac{n_m P}{120}$$

The frequency that used in Malaysia is about 50 Hz, so the generator will turn at fix speed depending on the number of poles. The magnitude of the voltage induced in stator is:

$$E_a = K\phi\omega \quad K = \text{constant}$$

The armature induced voltage phase is given by

$$V_\phi = E_a - jX I_A$$

The final equation

$$V_\phi = E_a - jX I_A - R_A I_A$$

## **2.8 Quality Of Supply**

The quality of electricity supply is based on the quality of the voltage provided to customers that can be affected various ways. The irregularities are sudden change in voltage, rapid fluctuation or unbalance of 3 phase voltage. The factor that affects the quality of supply is the actual value of supply voltage, which needed to be kept within a given range for correct application to customers. When the voltage is outside the range, it can badly damage the appliances. Extreme high voltage is usually due to failure on voltage control equipment, or over voltage.

### **Customer voltage regulation**

In order to determine the voltage variation, maximum and minimum loading must be known. The other factor also need to be taken such as due to transformer tap changer position and the transmission and distribution network must all be taken into account.

### **Low Voltage Supply**

In normal condition, voltage terminal shall not vary from system nominal voltage of 400/240 Volt by more than +10% to 6%

Under contingency condition, where one or more busbar are on outages, the steady state voltage at all point in distribution system shall be maintained at 400/230 V (+10% to -10%).

### **Medium Voltage Supply**

Normal condition- voltage to customers shall not vary from several nominal voltage of 11 kV by more than +5% to -5%.

Contingency conditions- one or more busbar are outages, steady state voltage at all point shall be planned to maintained at 11 kV within +10% to -10% of nominal voltage.

## **CHAPTER 3**

### **METHODOLOGY**


#### **3.1 Analysis Technique**

With rapid increase in population and industries, the electric distribution has grown in size and the number of the interconnection also has increased that make the system complex. For the better result, the study in this project was carried out by using computational simulation and modeling analysis software which are available in the EE department (ERACS software). The several advantages that ERACS has been chosen is:

- a) Competitive price against specification
- b) Low cost hardware platform
- c) User friendly interface
- d) Reliability
- e) Preparation of the data
  - multiple data input format
  - system MVA base
  - absolute unit
- f) Error checking of system configuration is simplified

### **3.2 Procedure Identification**

The projects begin with the research work on previous journals and books that have been published for the reference through out the project. A certain timeline was also been established in order to make the project flow smoothly. The first stage was to understand and identify the power system components in order to design and model a good power system. The working procedure mostly was on overview, investigation and research through the analysis. The workflow is shown below:



**Figure 10: Project process**

### **Phase 1 : Literature Research**

At this process, all the previous research and journals are studied which is the fundamental of the power system analysis and also the testing technique. Understanding the computer tools that will be using is also conducted during this stage, which is ERACS software.

### **Phase 2 :Design and modeling**

All the data that are required are compile together from others sources. It is very important to obtain the accurate data since it will be effect the equipment and electric power system of the distribution system. Assign a rite value which is acceptable.

### **Phase 3 : Simulation On Power Flow Study**

In order to perform this kind of testing technique. Several condition have been make and at this process, it will determine the actual value of the network voltage, current, real and reactive power.


### **Phase 4 : Simulation on Short Circuit Study**

This simulation is to determine the maximum current at the busbar of the network such as transformer and all major critical equipments.

Gantt chart for FYP

No.	Detail/ Week	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
1	Project Simulation				●											
2	Submission of Progress Report 1															
3	Project Work													●		
4	Submission of Progress Report 2															
5	Seminar													●		
6	Submission of Poster															
7	Project Work															
8	Submission of Softbound Dissertation															
9	Oral Presentation															
10	Submission of Hardbound Dissertation															

Mid-semester break



## **CHAPTER 4**

### **RESULT AND FINDINGS**

#### **4.1 Design Criteria**

Design and modeling power system is very important where the design enable the specified properties of the analysis to be obtained. A good design and the best practice at every stage, starting from the contractual framework and the consideration of the supply option is also being studied. While designing a power system, other criteria also have to be considered besides on the technical view, such as a comprehensive economic assessment of every project must be consider at the same time. As for the consequences, it must be unsure that the project proposed is technically sound and cost effective. Following studies are done during power system analysis:

#### An Industrial Viewpoint

- A) Feasibility studies- to ensure that the load flow and fault level proposal are acceptable and also the system has dynamic performance such as starting large drive, is needed.
- B) Detail design – undertaken when the project has been review. It will study the distribution system under all design loading requirement such as limiting reactance value on transformer and generator and also the starting current of the large motor.

Inside this system, the first incoming voltage, 132 kV is coming from 2 grid that somehow interconnect each other. The 132 kV voltage is then step down to 11 kV which is most of the system is then distributed using 11 kV voltage level that there is not much power losses if using lower voltage. The 11 kV systems are then stepdown again using transformer to the 415 V, which is then deliver to the customer. The network also consist of 1unit of generator that will generate it own electricity supply system. Network can be divided into heavy industrial load, industrial, and commercial and residential load. The, load itself are consisted of various PQ load, admittance and impedance load.

Below is the listing the basic elements that are using inside this system:

- 1) Busbar
- 2) 2 grid
- 3) 1 synchronous generator
- 4) Induction Motor
- 5) Neutral earthing
- 6) Line
- 7) Cable
- 8) Transformer
- 9) Shunt Load

Attached beside (**Figure 11**) is the design and modeling of the system under **normal condition**. See **Appendix A** for the power system component data sheet.




Figure11:Normal

## Grid Infeed




Figure 12: Input for Grid Infeed

Above figure show grid networks that are unaffected to the network. The grid infeed is model as an voltage behind an impedance. The three phase fault (MVA) and X/R ratio are used by the load flow to determine the initial impedance of the grid. ERACS is develop in UK, therefore it is common practice inside this software to specify MVA or kA.

## Busbar




Figure 13: Input for Busbar Data

Figure show the basic element of the busbar data. The main data that need to be inserted is the busbar voltage rating in kV and frequency (Hz). ERACS will automatically calculate the value of three phase fault rating (MVA) and single phase fault rating (MVA).

## Transformer




Figure 14: Input for Transformer Data

## Induction Motor




Figure 15: Input for Induction Motor Data

## Shunt Load




Figure 16: Input for Shunt Data

Inside the ERACS software, there are various type of load such as PQ load, admittance, constant current and impedance load.

## 4.2 Load Flow Study

The load flow study is being conducted with three contingency which are case 1: under normal, case 2: one busbar open, case 3: two busbar open, case 4: three busbar open which may occur due to maintenance or installation new equipment. Refer to the **Appendix B** for the load flow full result under case 1. For the case 2, busbar BB11-11kV was open (**Figure 17**). Load flow simulation have been perform and attached to **Appendix C**.

In case 3, busbar BB11-11kV and BB13-11kV was open (**Figure 18**). Refer to **Appendix D** for load flow simulation result. While in case 4, three busbar was open which are BB11-11kV, BB13-11kV and BB7-11kV (**Figure 19**) and refer to **Appendix E** for full result.


Below is the data for case study under normal and 3 contingency:

CASE	PG (MW)	QG (MVAr)	PL (MW)	QL (MVAr)	PLO (MW)	QLO (MVAr)
1	6.203	6.337	6.102	4.630	0.100	1.707
2	5.292	5.314	5.202	3.956	0.090	1.358
3	4.791	4.610	4.702	3.589	0.089	1.021
4	4.151	4.027	4.102	3.14	0.049	0.887


**Table 1: Load Flow Result**

From the table above, we can conclude that as increase in number of busbar open, the power generated also will tend to decrease. This is because to the decreasing of loads and line were shut down.

*PG=Total Real Power Generated, QG=Total Reactive Power Generated, PL=Total Real Power Load ,QL=Total Reactive Power Load, PLO=Total Real Power Losses, QLO= Total Reactive Power Losses*



**Figure 17: Busbar BB11-11kV OPEN**



#### 4.2.1 Cost Evaluation

Bus Selection Open	Real Power Generated (MW)	Reactive Power Generated (MVAr)	Real Power Loaded (MW)	Reactive Power Losses (MVAr)	Real Power Losses (MW)
S1	6.208	6.463	6.102	4.631	0.106
S2	6.208	6.465	6.102	4.627	0.106
S3	6.204	6.48	6.102	4.628	0.101
S4	6.203	6.480	6.102	4.628	0.101
S5	6.217	6.789	6.102	4.627	0.115
S6	5.292	5.314	5.202	3.956	0.090
S8	5.702	5.634	5.602	4.263	0.100
S9	5.600	5.430	5.502	4.128	0.098

Table 2 :Load Flow Summary Result

Load Characteristic:

60%- Domestic Area

40%- Industrial Area

Taking from TNB Tariff

Tariff A- Domestic Tariff

RM 0.28 per kW

Tariff E1- Medium Voltage General Industrial Tariff

RM 0.38 per kW

**For the Real Power Losses = 0.101MW**

$$60\% \times 0.101MW = 60.600kW - domestic$$

$$40\% \times 0.101MW = 40.400kW - industrial$$

For domestic tariff:

$$60.600kW \times RM 0.28 / kW = RM 16.968$$

Medium Voltage General Industrial:

$$40.400kW \times RM 0.30/kW = RM 12.12$$

Total Losses ,

$$RM 16.968 + RM 12.12 = \mathbf{RM 29}$$

**For Real Power Losses = 0.106 MW**

$$60\% \times 0.106MW = 63.600kW - domestic$$

$$40\% \times 0.106MW = 42.400kW - industrial$$

For domestic tariff:

$$63.600kW \times RM 0.28/kW = RM 17.808$$

Medium Voltage General Industrial:

$$42.400kW \times RM 0.30/kW = RM 12.72$$

Total Losses,

$$RM 17.808 + RM 12.72 = \mathbf{RM 31.58}$$

**For Real Power Losses = 0.115 MW**

$$60\% \times 0.115MW = 69.000kW - domestic$$

$$40\% \times 0.115MW = 46.000kW - industrial$$

For domestic tariff:

$$69.000kW \times RM 0.28/kW = RM 19.32$$

Medium Voltage General Industrial:

$$46.000kW \times RM 0.30/kW = RM 13.60$$

Total cost,

$$RM 19.32 + RM 13.60 = \mathbf{RM 33.12}$$

<b>BUS SELECTION</b>	<b>TOTAL LOSS(RM)</b>
S1	<b>RM 31.58</b>
S2	<b>RM 31.58</b>
S3	<b>RM 29.00</b>
S4	<b>RM 29.00</b>
S5	<b>RM 33.12</b>

**Table 3: Total Amount Of Losses**

From the table above, S3 and S4 yields the lowest amount of losses(in RM) to the system. Thus, it would be preferable to switch off S3 and S4. Noted that S6, S8 and S9 not chosen because when the bus selection turn off, it will not supply electricity to some of busbar, thus it is not applicable in this study.

#### 4.3 Short Circuit Study

In this case, end result was obtained from the simulation is to confirm that whether the existing busbar short circuit ratings are sufficient to withstand and interrupt the fault current. This also in order to verify that future loads will be available to the system. There are various type of fault such as :

- Three Phase
- Phase to earth
- Phase to phase
- Two Phase to earth

This study conduct under normal condition with several number of busbar are being perform the short circuit study

#### Short Circuit Study Setup




Figure 20: Short Circuit Study Setup Menu

#### 4.3.1 Three Phase Short Circuit

<b>Busbar</b>	<b>Ir(kA)</b>	<b>Iy(kA)</b>	<b>Ib(kA)</b>
BB1-415V	14.694	14.694	14.694
BB2-415V	12.703	12.703	12.703
BB3-415V	16.242	16.242	16.242
BB4-415V	13.806	13.806	13.806
BB5-415V	16.240	16.240	16.240
BB6-415V	13.498	13.498	13.498
BB7-415V	12.500	12.500	12.500
BB8-415V	17.665	17.665	17.665
BB9-415V	12.579	12.579	12.579
BB10-415V	15.655	15.655	15.655
BB11-415V	18.923	18.923	18.923
BB12-415V	18.797	18.797	18.797

**Table 4: Three Phase Short Circuit Study on Busbar 415V**

<b>Busbar</b>	<b>Ir(kA)</b>	<b>Iy(kA)</b>	<b>Ib(kA)</b>
BB1-11kV	2.38	2.38	2.38
BB2-11kV	2.38	2.38	2.38
BB3-11kV	2.384	2.384	2.384
BB4-11kV	2.384	2.384	2.384
BB5-11kV	2.384	2.384	2.384
BB6-11kV	2.384	2.384	2.384
BB7-11kV	2.384	2.384	2.384
BB8-11kV	2.384	2.384	2.384
BB9-11kV	1.208	1.208	1.208
BB10-11kV	2.235	2.235	2.235
BB11-11kV	2.235	2.235	2.235

BB12-11kV	9.516	9.516	9.516
BB13-11kV	1.207	1.207	1.207
BB14-11kV	1.207	1.207	1.207
BB15-11kV	1.207	1.207	1.207

**Table 5: Three Phase Short Circuit Study on Busbar 11kV**

Busbar	Ir(kA)	Iy(kA)	Ib(kA)
BB1-132kV	0.705	0.705	0.705
BB2-132kV	0.715	0.715	0.715
BB3-132kV	0.715	0.715	0.715

**Table 6: Three Phase Short Circuit Study on Busbar 132kV**

The most common short circuit technique to determine the protection equipment setting is a three phase short circuit study. Based on the TNB specification data, the maximum fault current must not exceed the below data:

Supply Voltage Level	Short Circuit Rating
132kV	31.5 kA for Three Phase
11kV	20 kA Three Phase
415V	31.5 kA Three Phase

**Table 7:Short Circuit Level for various Voltage Level**

#### **4.3.2 Phase to Earth, Two Phase to Earth and Phase to Phase Testing**

##### **Busbar BB4-11kV**

Fault Type	Ir(kA)	Iy(kA)	Ib(kA)
Phase to Earth	3.273	0	0
Two phase to earth	0	3.325	3.323
Phase to phase	0	2.067	2.067

**Table 8: Short Circuit at Busbar BB4-11kV**

##### **Busbar BB6-11kV**

Fault Type	Ir(kA)	Iy(kA)	Ib(kA)
Phase to Earth	3.273	0	0
Two phase to earth	0	3.325	3.323
Phase to phase	0	2.067	2.067

**Table 9: Short Circuit at Busbar BB6-11kV**

##### **Busbar BB14-11kV**

Fault Type	Ir(kA)	Iy(kA)	Ib(kA)
Phase to Earth	1.582	0	0
Two phase to earth	0	1.528	1.575
Phase to phase	0	1.045	1.045

**Table 10: Short Circuit at Busbar BB14-11kV**

From the table, when a fault occurs in an electrical power system, high current will be flows thus producing large amounts of unwanted energy in form of heat and magnetic forces. By determine the maximum fault current that would be occur during disturbance, it can ensures that a proper protective device setting that would invent from damage the equipment. The different value at each busbar was different because fault current depends on the internal impedance of the circuit.

## **CHAPTER 5**

### **CONCLUSION**

Based on the literature review and early research, power system analysis essential to the electrical engineer in order to design and modeling a certain system. Study, investigation and simulation need to be done in order to perform a good power system analysis and understanding the basic of the system. In order to get a stabilize system, several testing techniques was perform such as load flow and short circuit study. In order to perform this testing technique, we need to use power system software. Load Flow was a basically numerical analysis that important and the value that obtained from the load flow such as magnitude and angle of the voltage, real and reactive power at each branch and line. The short circuit study is performing in order to know the maximum fault that will be occur during disturbance.

#### **5.1 Recommendation**

Simulate using different software such as PSCAD, EDSA and etc. Thus, the result can be compare and improve the accuracy the result obtained.

## **REFERENCES**

1. “Power System Analysis”second edition  
By Hadi Saadat
2. “Electric Machinery Fundamentals” Fourth Edition  
Stephen J. Chapman
3. “Power System Analysis and Design”, third edition  
By J Duncan Glover and Mulukutla S.Sarma
4. “Electricity Distribution Network Design”, second edition  
By E.Lakervi and E.J Holmes
5. <http://www.dromeydesign.com/dess/loadFlow.php>
6. [http://www.cmbengineering.com/load\\_flow\\_study.html](http://www.cmbengineering.com/load_flow_study.html)
7. <http://ieeexplore.ieee.org/servlet/opac?punumber=11204>
8. [http://en.wikipedia.org/wiki/Electrical\\_substation](http://en.wikipedia.org/wiki/Electrical_substation)
9. Power System Analysis Software user and technical manual, ERACS

## **APPENDIX A: POWER SYSTEM COMPONENT**

Network Name : CASE4  
 Data State Name : BB11-11kV & BB13-11kV BB7OPEN

-----  
**SYSTEM STATISTICS**

Study Base MVA	=	100.000
Study Base Frequency (Hz)	=	50.000
Number of Busbars	=	30
Number of Shunts	=	10
Number of Lines	=	4
Number of Cables	=	0
Number of Transformers	=	15
Number of Tap Changers	=	0
Number of Synchronous Machines	=	3
Number of Induction Machines	=	3
Number of Wind Turbine Generators	=	0
Number of Bus Sections	=	10
Number of Series Elements	=	0

-----  
**STUDY PARAMETERS**

Load Power Multiplier	=	1.000000
Load Reactive Multiplier	=	1.000000
Convergence Tolerance	=	0.000005
Convergence Control	=	Method 2
Maximum Iterations	=	25
Overload Flag Level	=	100.0% Of Rating
Automatic Tap Changers		OFF

-----  
**BUSBAR DATA**

Busbar Identifier	Nominal kV	Three Phase Fault MVA	kA	Single Phase Fault MVA	kA	Transf. Shift Angle (deg.)	Nominal Bus Freq. (Hz)
BB 132kV	132.000	1500.0	6.561	2000.0	8.748	0.0	50.0
BB1-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB3-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB4-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB5-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB6-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB7-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB8-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB9-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB2-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB2 132kV	132.000	1500.0	6.561	2000.0	8.748	0.0	50.0
BB3 132kV	132.000	1500.0	6.561	2000.0	8.748	0.0	50.0
BB10-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB11-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB12-11kV	11.000	500.0	26.243	700.0	36.740	0.0	50.0
BB15-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB14-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB13-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB1-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB2-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB3-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB4-415V	0.415	31.0	43.127	45.0	62.604	0.0	50.0 NOT IN USE
BB5-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0

Run on 04-Jun-2009 by Supervisor from data set up on 04-Jun-2009 by supervisor

Network Name : CASE4

Data State Name : BB11-11kV & BB13-11kV BB7OPEN

**BUSBAR DATA**

Busbar Identifier	Nominal kV	Three Phase Fault		Single Phase Fault		Transf. Angle (deg.)	Shift Freq. (Hz)	Nominal Bus
		MVA	kA	MVA	kA			
BB6-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0	
BB7-415V	0.415	31.0	43.127	45.0	62.604	0.0	50.0	NOT IN USE
BB8-415V	0.415	31.0	43.127	45.0	62.604	30.0	50.0	
BB9-415V	0.415	31.0	43.127	45.0	62.604	0.0	50.0	NOT IN USE
BB10-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0	
BB11-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0	
BB12-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0	

**LINE DATA**

First Busbar	Second Busbar	Line Identifier	No.Of Ccts	Line Length	Library Key	Rating (kA)	Positive R(pu)	Sequence X(pu))	Sequence B(pu)	Zero R(pu)	Sequence X(pu)	Sequence B(pu)	Equivalent Pi Model
BB3-11kV	BB10-11kV	L1	1	2.00	Linel	0.459	0.16694	0.12793	0.00001	1.98347	0.50909	0.00000	
BB9-11kV	BB15-11kV	L2	1	1.00	Linel	7.000	0.00826	0.00701	0.00002	0.00826	0.00701	0.00002	
BB1-11kV	BB3-11kV	L3	1	1.00	Linel	7.000	0.00826	0.00701	0.00002	0.00826	0.00701	0.00002	
BB2-11kV	BB5-11kV	L4	1	1.00	Linel	7.000	0.00826	0.00701	0.00002	0.00826	0.00701	0.00002	

**TRANSFORMER DATA**

System Busbar	Winding No.	Rating (MVA)	Winding Type	Angle (deg.)	Pos/Neg. R(pu)	Sequence X(pu)	Zero Sequence R(pu)	Sequence X(pu)	Neutral R(pu)	Earth X(pu)	Voltage Ratio	Off-Nom Tap (%)
<b>DATA for Transformer with ID. T5</b>												

BB4-11kV	1	2.500	D	30.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
BB1-415V	2	2.500	YN	0.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00

BB5-11kV	1	1.500	D	30.00	0.0000	4.0000	0.1603	1.6033	0.0000	0.0000	1.0000	0.00
BB2-415V	2	1.500	YN	0.00	0.0000	4.0000	0.3333	1.6667	0.0000	0.0000	1.0434	0.00

BB6-11kV	1	2.000	D	30.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00
BB3-415V	2	2.000	YN	0.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00

KUN ON 04-JUN-2002 MY SUPERVISOR TELL ME AND SEE UP ON US WE WANT 2002 MY SUPERVISOR

Network Name : CASE4  
Data State Name : BB11-11kV & BB13-11kV BB7OP

## TRANSFORMER DATA

System Busbar	Winding No.	Rating (MVA)	Winding Type	Angle (deg.)	Pos/Neg. R(pu)	Sequence X(pu)	Zero Sequence R(pu)	Sequence X(pu)	Neutral R(pu)	Earth X(pu)	Voltage Ratio	Off-Nom Tap (%)
DATA for Transformer with ID. T8												
BB7-11kV	1	2.500	D	30.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00 OPEN AT SYSTEM BUS
BB4-415V	2	2.500	YN	0.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
DATA for Transformer with ID. T9												
BB8-11kV	1	2.000	D	30.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00
BB5-415V	2	2.000	YN	0.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00
DATA for Transformer with ID. T10												
BB10-11kV	1	2.500	D	30.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
BB6-415V	2	2.500	YN	0.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
DATA for Transformer with ID. T11												
BB11-11kV	1	1.500	D	30.00	0.0000	4.0000	0.1603	1.6033	0.0000	0.0000	1.0000	0.00 OPEN AT SYSTEM BUS
BB7-415V	2	1.500	YN	0.00	0.0000	4.0000	0.3333	1.6667	0.0000	0.0000	1.0434	0.00
DATA for Transformer with ID. T12												
BB12-11kV	1	2.500	D	30.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
BB8-415V	2	2.500	YN	0.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
DATA for Transformer with ID. T13												
BB13-11kV	1	2.000	D	30.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00 OPEN AT SYSTEM BUS
BB9-415V	2	2.000	YN	0.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00
DATA for Transformer with ID. T14												
BB14-11kV	1	2.500	D	30.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
BB10-415V	2	2.500	YN	0.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
DATA for Transformer with ID. T15												
BB15-11kV	1	2.500	D	30.00	0.0800	0.8000	0.0600	0.6000	0.0000	0.0000	1.0000	0.00
BB11-415V	2	2.500	YN	0.00	0.1600	1.9240	0.0800	1.4000	0.0000	0.0000	1.0000	0.00
BB12-415V	3	2.500	YN	0.00	0.0800	1.9240	0.0640	0.1400	0.0000	0.0000	1.0000	0.00

Network Name : CASE4

Data State Name : BB11-11kV & BB13-11kV BB7OPEN

-----  
TRANSFORMER DATA

System Busbar	Winding No.	Rating (MVA)	Winding Type	Angle (deg.)	Pos/Neg. R(pu)	Sequence X(pu)	Zero Sequence R(pu)	Sequence X(pu)	Neutral R(pu)	Earth X(pu)	Voltage Ratio	Off-Nom Tap (%)
DATA for Transformer with ID. T1												
BB 132kV	1	4.000	D	30.00	0.0000	3.3750	0.0591	0.5907	0.0000	0.0000	1.0000	0.00
BB1-11kV	2	4.000	YN	0.00	0.0000	3.3750	0.0591	0.5907	0.0000	0.0000	1.0000	0.00
DATA for Transformer with ID. T2												
BB 132kV	1	4.000	D	30.00	0.0000	3.3750	0.0591	0.5907	0.0000	0.0000	1.0000	0.00
BB2-11kV	2	4.000	YN	0.00	0.0000	3.3750	0.0591	0.5907	0.0000	0.0000	1.0000	0.00
DATA for Transformer with ID. T3												
BB2 132kV	1	6.000	D	30.00	0.0000	2.2500	0.0540	0.5390	0.0000	0.0000	1.0000	0.00
BB8-11kV	2	6.000	YN	0.00	0.0000	2.2500	0.0540	0.5390	0.0000	0.0000	1.0000	0.00
DATA for Transformer with ID. T4												
BB3 132kV	1	6.000	D	30.00	0.0000	2.2500	0.0540	0.5390	0.0000	0.0000	1.0000	0.00
BB9-11kV	2	6.000	YN	0.00	0.0000	2.2500	0.0540	0.5390	0.0000	0.0000	1.0000	0.00

-----  
INDUCTION MACHINE DATA

Busbar Identifier	Motor Identifier	No. Of Library Units	Library Key	Motor MVA	Ratings MW	Input kW	Slip MW	Stator (%)	Magnet. R(pu)	Standstill X(pu)	Rotor X(pu)	Running R(pu)	Running X(pu)
BB1-415V	IM1	1	M003	0.196	0.196	0.415	0.000	0.0000	0.0185	0.0918	5.8000	0.0215	0.1060
BB8-415V	IM2	1	M003	0.196	0.196	0.415	0.100	0.6837	0.0185	0.0918	5.8000	0.0215	0.1060
BB10-415V	IM3	1	M002	1.000	1.000	0.415	0.100	0.1340	0.0185	0.0918	5.8000	0.0215	0.1060

Network Name : CASE4  
 Data State Name : BB11-11kV & BB13-11kV BB7OPEN

-----  
**INFINITE GENERATOR DATA**

Busbar Identifier	Machine Identifier	Machine MVA	Ratings MW	kV	Assigned V(pu)	Pos. R(pu)	Sequence X(pu)	Neg. R(pu)	Sequence X(pu)	Zero R(pu)	Sequence X(pu)
BB 132kV	TNB A	150.00	14.93	132.00	1.000	0.0995	0.9950	0.0995	0.9950	0.0995	0.9950
BB2 132kV	TNB B	150.00	14.93	132.00	1.000	0.0995	0.9950	0.0995	0.9950	0.0995	0.9950

-----  
**SYNCHRONOUS MACHINE DATA**

Busbar Identifier	Machine Identifier	Type	No.Of Units	Library Key	Generator Ratings MVA BASE	MW	kV	Assigned V(pu)	MW	MVAR	Pos. R(pu)	Sequence X(pu)	Neg. R(pu)	Sequence X(pu)	Zero R(pu)	Sequence X(pu)
BB12-11kV	SG1	SLACK	1	GMIN	50.000	50.000	11.000	1.000	0.000	0.000	0.0120	0.2770	0.0200	0.1840	0.0150	0.0800

Neutral earthing  
 0.0000 0.0000 0.0000 0.0000

-----  
**SHUNT DATA**

Busbar Identifier	Shunt Identifier	No.of Units	Type	Library Key	Rating MVA	Positive/Negative Sequence	Data Values	Zero Sequence
BB2-415V	Load1	1	MW/pf	Ld1		1.000 MW	0.800 pf	
BB3-415V	Load2	1	G/B pu Base	SampleG/Bpu1	1.00	0.008 G pu	-0.006 B pu	0.008 G pu
BB4-415V	Load3	1	kW/pf	samplekW/pf		600.000 kW	0.800 pf	
BB5-415V	load 4	1	R/X Ohm	sampleR/X	1.50	100.000 R Ohm	75.000 X Ohm	100.000 R Ohm
BB6-415V	Load5	1	kW/pf	samplekW/pf		600.000 kW	0.800 pf	
BB7-415V	Load6	1	MW/pf	Ld2		0.900 MW	0.800 pf	
BB9-415V	load7	1	MW/pf	Ld1		0.500 MW	0.800 pf	
BB9-11kV		1	MW/MVAR	Load1		1.000 MW	0.750 MVAr	
BB11-415V	load8	1	MW/pf	Ld2		0.900 MW	0.800 pf	
BB12-415V	load9	1	MW/pf	Ld2		0.400 MW	0.800 pf	

Network Name : CASE4  
Data State Name : BB11-11kV & BB13-11kV BB7OPEN

-----  
**BUS SECTION DATA**  
-----

First Busbar	Second Busbar	Status
BB3-11kV	BB4-11kV	Closed
BB4-11kV	BB5-11kV	Closed
BB5-11kV	BB6-11kV	Closed
BB6-11kV	BB7-11kV	Closed
BB7-11kV	BB8-11kV	Closed
BB2 132kV	BB3 132kV	Closed
BB10-11kV	BB11-11kV	Closed
BB11-11kV	BB12-11kV	Open
BB13-11kV	BB14-11kV	Closed
BB14-11kV	BB15-11kV	Closed

-----

Network Name : CASE1  
 Data State Name : NORMAL

-----  
**SYSTEM STATISTICS**

Study Base MVA	=	100.000
Study Base Frequency (Hz)	=	50.000
Number of Busbars	=	30
Number of Shunts	=	10
Number of Lines	=	4
Number of Cables	=	0
Number of Transformers	=	15
Number of Tap Changers	=	0
Number of Synchronous Machines	=	3
Number of Induction Machines	=	3
Number of Wind Turbine Generators	=	0
Number of Bus Sections	=	10
Number of Series Elements	=	0

-----  
**STUDY PARAMETERS**

Load Power Multiplier	=	1.000000
Load Reactive Multiplier	=	1.000000
Convergence Tolerance	=	0.000005
Convergence Control	=	Method 2
Maximum Iterations	=	25
Overload Flag Level	=	100.0% Of Rating
Automatic Tap Changers		OFF

-----  
**BUSBAR DATA**

Busbar Identifier	Nominal kV	Three Phase Fault MVA	kA	Single Phase Fault MVA	kA	Transf. Shift Angle (deg.)	Nominal Bus Freq. (Hz)
BB 132kV	132.000	1500.0	6.561	2000.0	8.748	0.0	50.0
BB1-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB3-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB4-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB5-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB6-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB7-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB8-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB9-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB2-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB2 132kV	132.000	1500.0	6.561	2000.0	8.748	0.0	50.0
BB3 132kV	132.000	1500.0	6.561	2000.0	8.748	0.0	50.0
BB10-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB11-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB12-11kV	11.000	500.0	26.243	700.0	36.740	0.0	50.0
BB15-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB14-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB13-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB1-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB2-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB3-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB4-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB5-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0

Network Name : CASE1  
 Data State Name : NORMAL

-----  
**BUSBAR DATA**

Busbar Identifier	Nominal kV	Three Phase Fault		Single Phase Fault		Transf. Shift Angle (deg.)	Nominal Bus Freq. (Hz)
		MVA	kA	MVA	kA		
BB6-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB7-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB8-415V	0.415	31.0	43.127	45.0	62.604	30.0	50.0
BB9-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB10-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB11-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB12-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0

-----  
**LINE DATA**

First Busbar	Second Busbar	Line Identifier	No.Of Ccts	Line Length	Library Key	Rating (kA)	Positive R(pu)	Sequence X(pu)	Sequence B(pu)	Zero R(pu)	Sequence X(pu)	Sequence B(pu)	Equivalent Pi Model
BB3-11kV	BB10-11KV	L1	1	2.00	Line1	0.459	0.16694	0.12793	0.00001	1.98347	0.50909	0.00000	
BB9-11kV	BB15-11KV	L2	1	1.00	Line1	7.000	0.00826	0.00701	0.00002	0.00826	0.00701	0.00002	
BB1-11kV	BB3-11kV	L3	1	1.00	Line1	7.000	0.00826	0.00701	0.00002	0.00826	0.00701	0.00002	
BB2-11kV	BB5-11KV	L4	1	1.00	Line1	7.000	0.00826	0.00701	0.00002	0.00826	0.00701	0.00002	

-----  
**TRANSFORMER DATA**

System Busbar	Winding No.	Rating (MVA)	Winding Type	Angle (deg.)	Pos/Neg. R(pu)	Sequence X(pu)	Zero Sequence R(pu)	Sequence X(pu)	Neutral R(pu)	Earth X(pu)	Voltage Ratio	Off-Nom Tap (%)
---------------	-------------	--------------	--------------	--------------	----------------	----------------	---------------------	----------------	---------------	-------------	---------------	-----------------

DATA for Transformer with ID. T5                          No. of units 1 using library key T004  
 BB4-11kV        1      2.500      D      30.00      2.8000      2.8000      0.0938      0.9384      0.0000      0.0000      1.0000      0.00  
 BB1-415V        2      2.500      YN      0.00      2.8000      2.8000      0.0938      0.9384      0.0000      0.0000      1.0000      0.00

DATA for Transformer with ID. T6                          No. of units 1 using library key T006  
 BB5-11kV        1      1.500      D      30.00      0.0000      4.0000      0.1603      1.6033      0.0000      0.0000      1.0000      0.00  
 BB2-415V        2      1.500      YN      0.00      0.0000      4.0000      0.3333      1.6667      0.0000      0.0000      1.0434      0.00

DATA for Transformer with ID. T7                          No. of units 1 using library key T003  
 BB6-11kV        1      2.000      D      30.00      0.0000      3.0000      0.1176      1.1755      0.0000      0.0000      1.0000      0.00  
 BB3-415V        2      2.000      YN      0.00      0.0000      3.0000      0.1176      1.1755      0.0000      0.0000      1.0000      0.00

Network Name : CASE1  
 Data State Name : NORMAL

-----  
**TRANSFORMER DATA**

System Busbar	Winding No.	Rating (MVA)	Winding Type	Angle (deg.)	Pos/Neg. R(pu)	Sequence X(pu)	Zero Sequence R(pu)	Sequence X(pu)	Neutral R(pu)	Earth X(pu)	Voltage Ratio	Off-Nom Tap (%)
<b>DATA for Transformer with ID. T8</b>												
BB7-11kV	1	2.500	D	30.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
BB4-415V	2	2.500	YN	0.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T9</b>												
BB8-11kV	1	2.000	D	30.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00
BB5-415V	2	2.000	YN	0.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T10</b>												
BB10-11kV	1	2.500	D	30.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
BB6-415V	2	2.500	YN	0.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T11</b>												
BB11-11kV	1	1.500	D	30.00	0.0000	4.0000	0.1603	1.6033	0.0000	0.0000	1.0000	0.00
BB7-415V	2	1.500	YN	0.00	0.0000	4.0000	0.3333	1.6667	0.0000	0.0000	1.0434	0.00
<b>DATA for Transformer with ID. T12</b>												
BB12-11kV	1	2.500	D	30.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
BB8-415V	2	2.500	YN	0.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T13</b>												
BB13-11kV	1	2.000	D	30.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00
BB9-415V	2	2.000	YN	0.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T14</b>												
BB14-11kV	1	2.500	D	30.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
BB10-415V	2	2.500	YN	0.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T15</b>												
BB15-11kV	1	2.500	D	30.00	0.0800	0.8000	0.0600	0.6000	0.0000	0.0000	1.0000	0.00
BB11-415V	2	2.500	YN	0.00	0.1600	1.9240	0.0800	1.4000	0.0000	0.0000	1.0000	0.00
BB12-415V	3	2.500	YN	0.00	0.0800	1.9240	0.0640	0.1400	0.0000	0.0000	1.0000	0.00

Network Name : CASE1  
 Data State Name : NORMAL

**TRANSFORMER DATA**

System Busbar	Winding No.	Rating (MVA)	Winding Type	Angle (deg.)	Pos/Neg. R(pu)	Sequence X(pu)	Zero Sequence R(pu)	Sequence X(pu)	Neutral R(pu)	Earth X(pu)	Voltage Ratio	Off-Nom Tap (%)
DATA for Transformer with ID. T1												
BB 132kV	1	4.000	D	30.00	0.0000	3.3750	0.0591	0.5907	0.0000	0.0000	1.0000	0.00
BB1-11kV	2	4.000	YN	0.00	0.0000	3.3750	0.0591	0.5907	0.0000	0.0000	1.0000	0.00
DATA for Transformer with ID. T2												
BB 132kV	1	4.000	D	30.00	0.0000	3.3750	0.0591	0.5907	0.0000	0.0000	1.0000	0.00
BB2-11kV	2	4.000	YN	0.00	0.0000	3.3750	0.0591	0.5907	0.0000	0.0000	1.0000	0.00
DATA for Transformer with ID. T3												
BB2 132kV	1	6.000	D	30.00	0.0000	2.2500	0.0540	0.5390	0.0000	0.0000	1.0000	0.00
BB8-11kV	2	6.000	YN	0.00	0.0000	2.2500	0.0540	0.5390	0.0000	0.0000	1.0000	0.00
DATA for Transformer with ID. T4												
BB3 132kV	1	6.000	D	30.00	0.0000	2.2500	0.0540	0.5390	0.0000	0.0000	1.0000	0.00
BB9-11kV	2	6.000	YN	0.00	0.0000	2.2500	0.0540	0.5390	0.0000	0.0000	1.0000	0.00

**INDUCTION MACHINE DATA**

Busbar Identifier	Motor Identifier	No.Of Library Units Key	Motor Ratings MVA	Ratings MW	Input kv	Slip MW (%)	Stator R(pu)	Stator X(pu)	Magnet. X(pu)	Standstill R(pu)	Rotor X(pu)	Running R(pu)	Running X(pu)
BB1-415V	IM	1 M003	0.196	0.196	0.415	0.000	0.0000	0.0185	0.0918	5.8000	0.0215	0.1060	0.0134 0.1910
BB8-415V	IM2	1 M003	0.196	0.196	0.415	0.100	0.6837	0.0185	0.0918	5.8000	0.0215	0.1060	0.0134 0.1910
BB10-415V	IM3	1 M002	1.000	1.000	0.415	0.100	0.1340	0.0185	0.0918	5.8000	0.0215	0.1060	0.0134 0.1910

Network Name : CASE1  
Data State Name : NORMAL

-----  
INFINITE GENERATOR DATA

Busbar Identifier	Machine Identifier	Machine MVA	Ratings MW	kV	Assigned V(pu)	Pos. R(pu)	Sequence X(pu)	Neg. R(pu)	Sequence X(pu)	Zero Sequence R(pu)	Sequence X(pu)
BB 132kV	TNB A	150.00	14.93	132.00	1.000	0.0995	0.9950	0.0995	0.9950	0.0995	0.9950
BB2 132kV	TNB B	150.00	14.93	132.00	1.000	0.0995	0.9950	0.0995	0.9950	0.0995	0.9950

-----  
SYNCHRONOUS MACHINE DATA

Busbar Identifier	Machine Identifier	Type	No.Of Units	Library Key	Generator MVA BASE	Ratings MW	kV	Assigned V(pu)	MW	MVAR	Pos. R(pu)	Sequence X(pu)	Neg. R(pu)	Sequence X(pu)	Zero Sequence R(pu)	Sequence X(pu)
BB12-11kV	SG1	SLACK	1	GMIN	50.000	50.000	11.000	1.000	0.000	0.000	0.0120	0.2770	0.0200	0.1840	0.0150	0.0800

-----  
SHUNT DATA

Busbar Identifier	Shunt Identifier	No.Of Units	Type	Library Key	Rating MVA	Positive/Negative Sequence		Data Values		Zero Sequence			
BB2-415V	Load1	1	MW/pf	Ld1		1.000	MW	0.800	pf				
BB3-415V	Load2	1	G/B pu Base	SampleG/Bpu1	1.00	0.008	G pu	-0.006	B pu	0.008	G pu	-0.006	B pu
BB4-415V	Load3	1	kW/pf	samplekW/pf		600.000	kW	0.800	pf				
BB5-415V	load 4	1	R/X Ohm	sampleR/X	1.50	100.000	R Ohm	75.000	X Ohm	100.000	R Ohm	75.000	X Ohm
BB6-415V	Load5	1	kW/pf	samplekW/pf		600.000	kW	0.800	pf				
BB7-415V	Load6	1	MW/pf	Ld2		0.900	MW	0.800	pf				
BB9-415V	load7	1	MW/pf	Ld1		0.500	MW	0.800	pf				
BB9-11kV		1	MW/MVAR	Load1		1.000	MW	0.750	MVar				
BB11-415V	load8	1	MW/pf	Ld2		0.900	MW	0.800	pf				
BB12-415V	load9	1	MW/pf	Ld2		0.400	MW	0.800	pf				

Network Name : CASE1  
Data State Name : NORMAL

-----  
BUS SECTION DATA  
-----

First Busbar	Second Busbar	Status
BB3-11kV	BB4-11kV	Closed
BB4-11kV	BB5-11kV	Closed
BB5-11kV	BB6-11kV	Closed
BB6-11kV	BB7-11kV	Closed
BB7-11kV	BB8-11kV	Closed
BB2 132kV	BB3 132kV	Closed
BB10-11kV	BB11-11kV	Closed
BB11-11kV	BB12-11kV	Open
BB13-11kV	BB14-11kV	Closed
BB14-11kV	BB15-11kV	Closed

Network Name : CASE1  
 Data State Name : NORMAL

AT STUDY END - No of iterations = 4 Convergence = 0.1125E-05  
 Voltage Range from 0.839pu at BB11-415V to 1.000pu at BB 132kV

AC BUSBAR VALUES

Busbar Identifier	Merge	Busbar Type	Voltage PU	Voltage kV ANG-DEG		Synch. Machines MW MVAr		Ind Motor Load MW MVAr		Shunt Loads MW MVAr		3 Phase Fault kA X/R		Ph - E Fault kA X/R	
				kV	ANG-DEG	MW	MVAr	MW	MVAr	MW	MVAr	kA	X/R	kA	X/R
BB 132kV	.	INF.BUS	1.000	132.000	0.000	1.967	1.794	0.000	0.000	0.000	0.000	0.71	11.315	0.68	9.898
BB2 132kV	M6	INF.BUS	1.000	132.000	-0.685	4.134	4.495	0.000	0.000	0.000	0.000	0.72	11.345	0.69	9.025
BB3 132kV	M6	LOAD	1.000	132.000	-0.685	0.000	0.000	0.000	0.000	0.000	0.000	0.72	11.345	0.69	9.025
BB12-11kV	.	SLACK	1.000	11.000	2.093	0.101	0.048	0.000	0.000	0.000	0.000	9.51	22.816	14.55	11.459
BB1-11kV	.	LOAD	0.942	10.360	-4.043	0.000	0.000	0.000	0.000	0.000	0.000	2.38	10.865	3.26	10.677
BB10-11kV	M7	LOAD	0.937	10.309	-4.030	0.000	0.000	0.000	0.000	0.000	0.000	2.24	6.206	2.50	1.923
BB11-11kV	M7	LOAD	0.937	10.309	-4.030	0.000	0.000	0.000	0.000	0.000	0.000	2.24	6.206	2.50	1.923
BB13-11kV	M9	LOAD	0.867	9.540	-9.363	0.000	0.000	0.000	0.000	0.000	0.000	1.21	5.189	1.58	5.501
BB14-11kV	M9	LOAD	0.867	9.540	-9.363	0.000	0.000	0.000	0.000	0.000	0.000	1.21	5.189	1.58	5.501
BB15-11kV	M9	LOAD	0.867	9.540	-9.363	0.000	0.000	0.000	0.000	0.000	0.000	1.21	5.189	1.58	5.501
BB2-11kV	.	LOAD	0.942	10.360	-4.043	0.000	0.000	0.000	0.000	0.000	0.000	2.38	10.865	3.26	10.677
BB3-11kV	M3	LOAD	0.942	10.358	-4.043	0.000	0.000	0.000	0.000	0.000	0.000	2.38	11.064	3.27	10.922
BB4-11kV	M3	LOAD	0.942	10.358	-4.043	0.000	0.000	0.000	0.000	0.000	0.000	2.38	11.064	3.27	10.922
BB5-11kV	M3	LOAD	0.942	10.358	-4.043	0.000	0.000	0.000	0.000	0.000	0.000	2.38	11.064	3.27	10.922
BB6-11kV	M3	LOAD	0.942	10.358	-4.043	0.000	0.000	0.000	0.000	0.000	0.000	2.38	11.064	3.27	10.922
BB7-11kV	M3	LOAD	0.942	10.358	-4.043	0.000	0.000	0.000	0.000	0.000	0.000	2.38	11.064	3.27	10.922
BB8-11kV	M3	LOAD	0.942	10.358	-4.043	0.000	0.000	0.000	0.000	0.000	0.000	2.38	11.064	3.27	10.922
BB9-11kV	.	LOAD	0.868	9.544	-9.363	0.000	0.000	0.000	0.000	1.000	0.750	1.21	5.228	1.59	5.564
BB1-415V	.	LOAD	0.940	0.390	-3.937	0.000	0.000	0.000	0.029	0.000	0.000	14.69	1.468	20.14	1.625
BB10-415V	.	LOAD	0.852	0.354	-9.247	0.000	0.000	0.100	0.127	0.000	0.000	15.66	2.416	20.97	2.654
BB11-415V	.	LOAD	0.839	0.348	-11.399	0.000	0.000	0.000	0.000	0.900	0.675	18.92	4.907	24.44	5.412
BB12-415V	.	LOAD	0.849	0.352	-10.692	0.000	0.000	0.000	0.000	0.400	0.300	18.80	5.897	26.61	5.900
BB2-415V	.	LOAD	0.906	0.376	-9.660	0.000	0.000	0.000	0.000	1.000	0.750	12.70	7.406	16.13	7.275
BB3-415V	.	LOAD	0.942	0.391	-4.047	0.000	0.000	0.000	0.000	0.001	0.001	16.24	43.061	21.25	30.309
BB4-415V	.	LOAD	0.874	0.363	-4.628	0.000	0.000	0.000	0.000	0.600	0.450	13.81	1.270	18.97	1.418
BB5-415V	.	LOAD	0.942	0.391	-4.047	0.000	0.000	0.000	0.000	0.001	0.001	16.24	43.061	21.25	30.309
BB6-415V	.	LOAD	0.869	0.361	-4.621	0.000	0.000	0.000	0.000	0.600	0.450	13.50	1.253	18.58	1.398
BB7-415V	.	LOAD	0.909	0.377	-9.088	0.000	0.000	0.000	0.000	0.900	0.675	12.50	7.172	15.92	7.083
BB8-415V	.	LOAD	0.992	0.412	1.923	0.000	0.000	0.100	0.047	0.000	0.000	17.67	1.203	24.20	1.345
BB9-415V	.	LOAD	0.840	0.349	-11.724	0.000	0.000	0.000	0.000	0.500	0.375	12.58	7.726	16.74	7.930

Network Name : CASE1  
 Data State Name : NORMAL

BUSBAR TOTALS	6.203	6.337	0.200	0.204	5.902	4.426
TOTAL BUS LOAD	6.102	4.630				
SYSTEM LOSSES	0.100	1.707				

-----  
**LINE VALUES**

First Busbar	Second Busbar	Branch Identifier	No.Of Ccts	Rating kA	First MW	End MVAr	Flow kA	Second MW	End MVAr	Flow kA	Loading (%)	O/L FLAG
BB3-11kV	BB10-11kV	L1	1	0.459	1.549	1.305	0.113	-1.542	-1.300	0.113	24.6	
BB9-11kV	BB15-11kV	L2	1	7.000	1.909	1.582	0.150	-1.908	-1.583	0.150	2.1	
BB1-11kV	BB3-11kV	L3	1	7.000	0.984	0.777	0.070	-0.984	-0.779	0.070	1.0	
BB2-11kV	BB5-11kV	L4	1	7.000	0.984	0.777	0.070	-0.984	-0.779	0.070	1.0	

-----  
**TRANSFORMER VALUES**

Transformer Identifier	No.Of Units	Winding No.	Connected Busbar	Winding kv	Voltage Ratio	Off Nominal Tap %	Rating MVA	Flow From Busbar MW	Current MVar	Percent O/L Loading	O/L Flag
T5	1	1	BB4-11kV	11.000	1.0000	0.000	2.500	0.000	0.029	0.002	1.2
		2	BB1-415V	0.415	1.0000	0.000	2.500	0.000	-0.029	0.043	1.2
T6	1	1	BB5-11kV	11.000	1.0000	0.000	1.500	1.000	0.916	0.076	90.4
		2	BB2-415V	0.433	1.0434	0.000	1.500	-1.000	-0.750	1.920	83.3
T7	1	1	BB6-11kV	11.000	1.0000	0.000	2.000	0.001	0.001	0.000	0.1
		2	BB3-415V	0.415	1.0000	0.000	2.000	-0.001	-0.001	0.002	0.1
T8	1	1	BB7-11kV	11.000	1.0000	0.000	2.500	0.641	0.491	0.045	32.3
		2	BB4-415V	0.415	1.0000	0.000	2.500	-0.600	-0.450	1.193	30.0
T9	1	1	BB8-11kV	11.000	1.0000	0.000	2.000	0.001	0.001	0.000	0.1
		2	BB5-415V	0.415	1.0000	0.000	2.000	-0.001	-0.001	0.002	0.1
T10	1	1	BB10-11kV	11.000	1.0000	0.000	2.500	0.642	0.492	0.045	32.3
		2	BB6-415V	0.415	1.0000	0.000	2.500	-0.600	-0.450	1.200	30.0
T11	1	1	BB11-11kV	11.000	1.0000	0.000	1.500	0.900	0.808	0.068	80.6
		2	BB7-415V	0.433	1.0434	0.000	1.500	-0.900	-0.675	1.721	75.0
T12	1	1	BB12-11kV	11.000	1.0000	0.000	2.500	0.101	0.048	0.006	4.5
		2	BB8-415V	0.415	1.0000	0.000	2.500	-0.100	-0.047	0.155	4.4

Network Name : CASE1  
 Data State Name : NORMAL

-----  
**TRANSFORMER VALUES**

Transformer Identifier	No.Of Units	Winding No.	Connected Busbar	Winding kV	Voltage Ratio	Off Nominal Tap %	Rating MVA	Flow From MW	Busbar MVar	Current kA	Percent O/L Loading Flag
T13	1	1	BB13-11kV	11.000	1.0000	0.000	2.000	0.500	0.408	0.039	32.3
		2	BB9-415V	0.415	1.0000	0.000	2.000	-0.500	-0.375	1.035	31.2
T14	1	1	BB14-11kV	11.000	1.0000	0.000	2.500	0.102	0.129	0.010	6.6
		2	BB10-415V	0.415	1.0000	0.000	2.500	-0.100	-0.127	0.263	6.5
T15	1	1	BB15-11kV	11.000	1.0000	0.000	2.500	1.306	1.046	0.101	66.9
		2	BB11-415V	0.415	1.0000	0.000	2.500	-0.900	-0.675	1.865	45.0
		3	BB12-415V	0.415	1.0000	0.000	2.500	-0.400	-0.300	0.819	20.0
T1	1	1	BB 132kV	132.000	1.0000	0.000	4.000	0.984	0.897	0.006	33.3
		2	BB1-11kV	11.000	1.0000	0.000	4.000	-0.984	-0.777	0.070	31.3
T2	1	1	BB 132kV	132.000	1.0000	0.000	4.000	0.984	0.897	0.006	33.3
		2	BB2-11kV	11.000	1.0000	0.000	4.000	-0.984	-0.777	0.070	31.3
T3	1	1	BB2 132kV	132.000	1.0000	0.000	6.000	1.226	1.332	0.008	30.2
		2	BB8-11kV	11.000	1.0000	0.000	6.000	-1.226	-1.185	0.095	28.4
T4	1	1	BB3 132kV	132.000	1.0000	0.000	6.000	2.909	3.163	0.019	71.6
		2	BB9-11kV	11.000	1.0000	0.000	6.000	-2.909	-2.332	0.226	62.1

-----  
**BRANCH LOSS SUMMARY**

	(MW)	(MVar)
SERIES LOSSES	0.100	1.713
SHUNT LOSSES	0.000	-0.006
TOTAL LOSSES	0.100	1.707

Network Name : CASE1  
Data State Name : NORMAL

-----  
INDUCTION MACHINE VALUES

Busbar Identifier	Machine Identifier	No.Of Units	Slip %	Terminal Voltage kV	Machine MW	Input MVAr	Current kA	O/L Flag
BB1-415V	IM	1	0.00	0.390	0.000	0.029	0.043	
BB8-415V	IM2	1	0.74	0.412	0.100	0.047	0.155	
BB10-415V	IM3	1	0.19	0.354	0.100	0.127	0.263	

-----  
SYNCHRONOUS MACHINE VALUES

Busbar Identifier	Machine Identifier	No.Of Units	Terminal Voltage kV	Power MW	Output MVAr	Current kA	O/L Flag
BB 132kV	TNB A	1	132.000	1.967	1.794	0.012	
BB2 132kV	TNB B	1	132.000	4.134	4.495	0.027	
BB12-11kV	SG1	1	11.000	0.101	0.048	0.006	

-----  
SHUNT VALUES

Busbar Identifier	Shunt Identifier	Shunt MW	Load MVAr	Current kA	O/L Flag
BB2-415V	Load1	1.000	0.750	1.920	
BB3-415V	Load2	0.001	0.001	0.002	
BB4-415V	Load3	0.600	0.450	1.193	
BB5-415V	load 4	0.001	0.001	0.002	
BB6-415V	Load5	0.600	0.450	1.200	
BB7-415V	Load6	0.900	0.675	1.721	
BB9-415V	load7	0.500	0.375	1.035	
BB9-11kV		1.000	0.750	0.076	
BB11-415V	load8	0.900	0.675	1.865	
BB12-415V	load9	0.400	0.300	0.819	

Network Name : CASE1  
Data State Name : NORMAL

BUS SECTION VALUES

First Busbar	Second Busbar	MW	MVAr	kA
BB3-11kV	BB4-11kV	-0.566	-0.526	0.043
BB4-11kV	BB5-11kV	-0.566	-0.556	0.044
BB5-11kV	BB6-11kV	-0.582	-0.692	0.050
BB6-11kV	BB7-11kV	-0.583	-0.693	0.050
BB7-11kV	BB8-11kV	-1.225	-1.184	0.095
BB2 132kV	BB3 132kV	2.909	3.163	0.019
BB10-11kV	BB11-11kV	0.900	0.808	0.068
BB11-11kV	BB12-11kV	0.000	0.000	0.000
BB13-11kV	BB14-11kV	-0.500	-0.408	0.039
BB14-11kV	BB15-11kV	-0.602	-0.537	0.049

Network Name : CASE2  
 Data State Name : BB11-11kV OPEN

-----  
**SYSTEM STATISTICS**

Study Base MVA	=	100.000
Study Base Frequency (Hz)	=	50.000
Number of Busbars	=	30
Number of Shunts	=	10
Number of Lines	=	4
Number of Cables	=	0
Number of Transformers	=	15
Number of Tap Changers	=	0
Number of Synchronous Machines	=	3
Number of Induction Machines	=	3
Number of Wind Turbine Generators	=	0
Number of Bus Sections	=	10
Number of Series Elements	=	0

-----  
**STUDY PARAMETERS**

Load Power Multiplier	=	1.000000
Load Reactive Multiplier	=	1.000000
Convergence Tolerance	=	0.000005
Convergence Control	=	Method 2
Maximum Iterations	=	25
Overload Flag Level	=	100.0% Of Rating
Automatic Tap Changers		OFF

-----  
**BUSBAR DATA**

Busbar Identifier	Nominal kV	Three Phase Fault MVA	kA	Single Phase Fault MVA	kA	Transf. Shift Angle (deg.)	Nominal Bus Freq. (Hz)
BB 132kV	132.000	1500.0	6.561	2000.0	8.748	0.0	50.0
BB1-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB3-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB4-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB5-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB6-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB7-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB8-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB9-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB2-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB2 132kV	132.000	1500.0	6.561	2000.0	8.748	0.0	50.0
BB3 132kV	132.000	1500.0	6.561	2000.0	8.748	0.0	50.0
BB10-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB11-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB12-11kV	11.000	500.0	26.243	700.0	36.740	0.0	50.0
BB15-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB14-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB13-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB1-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB2-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB3-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB4-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB5-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0

Network Name : CASE2  
 Data State Name : BB11-11kV OPEN

-----  
**BUSBAR DATA**

Busbar Identifier	Nominal kV	Three Phase Fault MVA	Fault kA	Single Phase Fault MVA	Fault kA	Transf. Shift Angle (deg.)	Nominal Bus Freq. (Hz)
BB6-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB7-415V	0.415	31.0	43.127	45.0	62.604	0.0	50.0 NOT IN USE
BB8-415V	0.415	31.0	43.127	45.0	62.604	30.0	50.0
BB9-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB10-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB11-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB12-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0

-----  
**LINE DATA**

First Busbar	Second Busbar	Line Identifier	No.Of Ccts	Line Length	Library Key	Rating (kA)	Positive R(pu)	Sequence X(pu)	Sequence B(pu)	Zero R(pu)	Sequence X(pu)	Sequence B(pu)	Equivalent Pi Model
BB3-11kV	BB10-11kV	L1	1	2.00	Line1	0.459	0.16694	0.12793	0.00001	1.98347	0.50909	0.00000	
BB9-11kV	BB15-11kV	L2	1	1.00	Line1	7.000	0.00826	0.00701	0.00002	0.00826	0.00701	0.00002	
BB1-11kV	BB3-11kV	L3	1	1.00	Line1	7.000	0.00826	0.00701	0.00002	0.00826	0.00701	0.00002	
BB2-11kV	BB5-11kV	L4	1	1.00	Line1	7.000	0.00826	0.00701	0.00002	0.00826	0.00701	0.00002	

-----  
**TRANSFORMER DATA**

System Busbar	Winding No.	Rating (MVA)	Winding Type	Angle (deg.)	Pos/Neg. R(pu)	Sequence X(pu)	Zero Sequence R(pu)	Sequence X(pu)	Neutral R(pu)	Earth X(pu)	Voltage Ratio	Off-Nom Tap (%)
DATA for Transformer with ID. T5												
BB4-11kV	1	2.500	D	30.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
BB1-415V	2	2.500	YN	0.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
DATA for Transformer with ID. T6												
BB5-11kV	1	1.500	D	30.00	0.0000	4.0000	0.1603	1.6033	0.0000	0.0000	1.0000	0.00
BB2-415V	2	1.500	YN	0.00	0.0000	4.0000	0.3333	1.6667	0.0000	0.0000	1.0434	0.00
DATA for Transformer with ID. T7												
BB6-11kV	1	2.000	D	30.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00
BB3-415V	2	2.000	YN	0.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00

Network Name : CASE2  
 Data State Name : BB11-11kV OPEN

-----  
**TRANSFORMER DATA**

System Busbar	Winding No.	Rating (MVA)	Winding Type	Angle (deg.)	Pos/Neg. R(pu)	Sequence X(pu)	Zero Sequence R(pu)	Sequence X(pu)	Neutral R(pu)	Earth X(pu)	Voltage Ratio	Off-Nom Tap (%)
<b>DATA for Transformer with ID. T8</b>												
BB7-11kV	1	2.500	D	30.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
BB4-415V	2	2.500	YN	0.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T9</b>												
BB8-11kV	1	2.000	D	30.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00
BB5-415V	2	2.000	YN	0.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T10</b>												
BB10-11kV	1	2.500	D	30.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
BB6-415V	2	2.500	YN	0.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T11</b>												
BB11-11kV	1	1.500	D	30.00	0.0000	4.0000	0.1603	1.6033	0.0000	0.0000	1.0000	0.00
BB7-415V	2	1.500	YN	0.00	0.0000	4.0000	0.3333	1.6667	0.0000	0.0000	1.0434	0.00
<b>DATA for Transformer with ID. T12</b>												
BB12-11kV	1	2.500	D	30.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
BB8-415V	2	2.500	YN	0.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T13</b>												
BB13-11kV	1	2.000	D	30.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00
BB9-415V	2	2.000	YN	0.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T14</b>												
BB14-11kV	1	2.500	D	30.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
BB10-415V	2	2.500	YN	0.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T15</b>												
BB15-11kV	1	2.500	D	30.00	0.0800	0.8000	0.0600	0.6000	0.0000	0.0000	1.0000	0.00
BB11-415V	2	2.500	YN	0.00	0.1600	1.9240	0.0800	1.4000	0.0000	0.0000	1.0000	0.00
BB12-415V	3	2.500	YN	0.00	0.0800	1.9240	0.0640	0.1400	0.0000	0.0000	1.0000	0.00

Network Name : CASE2  
 Data State Name : BB11-11kV OPEN

-----  
**TRANSFORMER DATA**

System Busbar	Winding No.	Rating (MVA)	Winding Type	Angle (deg.)	Pos/Neg. R(pu)	Sequence X(pu)	Zero Sequence R(pu)	Sequence X(pu)	Neutral R(pu)	Earth X(pu)	Voltage Ratio	Off-Nom Tap (%)
<b>DATA for Transformer with ID. T1</b>												
BB 132kV	1	4.000	D	30.00	0.0000	3.3750	0.0591	0.5907	0.0000	0.0000	1.0000	0.00
BB1-11kV	2	4.000	YN	0.00	0.0000	3.3750	0.0591	0.5907	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T2</b>												
BB 132kV	1	4.000	D	30.00	0.0000	3.3750	0.0591	0.5907	0.0000	0.0000	1.0000	0.00
BB2-11kV	2	4.000	YN	0.00	0.0000	3.3750	0.0591	0.5907	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T3</b>												
BB2 132kV	1	6.000	D	30.00	0.0000	2.2500	0.0540	0.5390	0.0000	0.0000	1.0000	0.00
BB8-11kV	2	6.000	YN	0.00	0.0000	2.2500	0.0540	0.5390	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T4</b>												
BB3 132kV	1	6.000	D	30.00	0.0000	2.2500	0.0540	0.5390	0.0000	0.0000	1.0000	0.00
BB9-11kV	2	6.000	YN	0.00	0.0000	2.2500	0.0540	0.5390	0.0000	0.0000	1.0000	0.00

-----  
**INDUCTION MACHINE DATA**

Busbar Identifier	Motor Identifier	No. Of Library Units	Library Key	Motor Ratings			Input MW	Slip (%)	Stator R(pu)	Stator X(pu)	Magnet. X(pu)	Standstill R(pu)	Standstill X(pu)	Rotor R(pu)	Rotor X(pu)	Running
				MVA	MW	kV										
BB1-415V	IM	1	M003	0.196	0.196	0.415	0.000	0.0000	0.0185	0.0918	5.8000	0.0215	0.1060	0.0134	0.1910	
BB8-415V	IM2	1	M003	0.196	0.196	0.415	0.100	0.6837	0.0185	0.0918	5.8000	0.0215	0.1060	0.0134	0.1910	
BB10-415V	IM3	1	M002	1.000	1.000	0.415	0.100	0.1340	0.0185	0.0918	5.8000	0.0215	0.1060	0.0134	0.1910	

Network Name : CASE2  
 Data State Name : BB11-11kV OPEN

INFINITE GENERATOR DATA

Busbar Identifier	Machine Identifier	Machine MVA	Ratings MW	kV	Assigned V(pu)	Pos. R(pu)	Sequence X(pu)	Neg. R(pu)	Sequence X(pu)	Zero R(pu)	Sequence X(pu)
BB1 132kV	TNB A	150.00	14.93	132.00	1.000	0.0995	0.9950	0.0995	0.9950	0.0995	0.9950
BB2 132kV	TNB B	150.00	14.93	132.00	1.000	0.0995	0.9950	0.0995	0.9950	0.0995	0.9950

SYNCHRONOUS MACHINE DATA

Busbar Identifier	Machine Identifier	Type	No.Of Units	Library Key	Generator Ratings			Assigned			Pos. Sequence			Neg. Sequence			Zero Sequence		
					MVA BASE	MW	kV	V(pu)	MW	MVAR	R(pu)	X(pu)	R(pu)	X(pu)	R(pu)	X(pu)	R(pu)	X(pu)	
BB12-11kV	SG1	SLACK	1	GMIN	50.000	50.000	11.000	1.000	0.000	0.000	0.0120	0.2770	0.0200	0.1840	0.0150	0.0800	0.0000	0.0000	
					Neutral earthing						0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	

SHUNT DATA

Busbar Identifier	Shunt Identifier	No.Of Units	Type	Library Key	Rating MVA	Data Values			Zero Sequence	
						Positive/Negative Sequence	MW	pf		
BB2-415V	Load1	1	MW/pf	Ld1		1.000	MW	0.800 pf		
BB3-415V	Load2	1	G/B pu Base	SampleG/Bpu1	1.00	0.008	G pu	-0.006 B pu	0.008 G pu	-0.006 B pu
BB4-415V	Load3	1	kW/pf	samplekW/pf		600.000	kW	0.800 pf		
BB5-415V	load 4	1	R/X Ohm	sampleR/X	1.50	100.000	R Ohm	75.000 X Ohm	100.000 R Ohm	75.000 X Ohm
BB6-415V	Load5	1	kW/pf	samplekW/pf		600.000	kW	0.800 pf		
BB7-415V	Load6	1	MW/pf	Ld2		0.900	MW	0.800 pf		
BB9-415V	load7	1	MW/pf	Ld1		0.500	MW	0.800 pf		
BB9-11kV		1	MW/MVAR	Load1		1.000	MW	0.750 MVAr		
BB11-415V	load8	1	MW/pf	Ld2		0.900	MW	0.800 pf		
BB12-415V	load9	1	MW/pf	Ld2		0.400	MW	0.800 pf		

Network Name : CASE2  
Data State Name : BB11-11kV OPEN

-----  
BUS SECTION DATA  
-----

First Busbar	Second Busbar	Status
BB3-11kV	BB4-11kV	Closed
BB4-11kV	BB5-11kV	Closed
BB5-11kV	BB6-11kV	Closed
BB6-11kV	BB7-11kV	Closed
BB7-11kV	BB8-11kV	Closed
BB2 132kV	BB3 132kV	Closed
BB10-11kV	BB11-11kV	Closed
BB11-11kV	BB12-11kV	Open
BB13-11kV	BB14-11kV	Closed
BB14-11kV	BB15-11kV	Closed

-----

Network Name : CASE2  
Data State Name : BB11-11kV OPEN

AT STUDY END - No of iterations = 4 Convergence = 0.1132E-05  
Voltage Range from 0.839pu at BB11-415V to 1.000pu at BB 132kV

### AC BUSBAR VALUES

Network Name : CASE2  
 Data State Name : BB11-11kV OPEN

BUSBAR TOTALS	5.292	5.314	0.200	0.205	5.002	3.752
TOTAL BUS LOAD	5.202	3.956				
SYSTEM LOSSES	0.090	1.358				

-----  
**LINE VALUES**

First Busbar	Second Busbar	Branch Identifier	No.Of Ccts	Rating kA	First MW	End MVAR	Flow kA	Second MW	End MVAR	Flow kA	Loading (%)	O/L FLAG
BB3-11kV	BB10-11kV	L1	1	0.459	0.641	0.490	0.044	-0.640	-0.490	0.044	9.6	
BB9-11kV	BB15-11kV	L2	1	7.000	1.909	1.582	0.150	-1.908	-1.583	0.150	2.1	
BB1-11kV	BB3-11kV	L3	1	7.000	0.729	0.543	0.050	-0.729	-0.545	0.050	0.7	
BB2-11kV	BB5-11kV	L4	1	7.000	0.729	0.543	0.050	-0.729	-0.545	0.050	0.7	

-----  
**TRANSFORMER VALUES**

Transformer Identifier	No.Of Units	Winding No.	Connected Busbar	Winding kV	Voltage Ratio	Off Tap %	Nominal	Rating MVA	Flow From Busbar MW	Current kA	Percent O/L Loading	O/L Flag
T5	1	1	BB4-11kV	11.000	1.0000	0.000	2.500	0.000	0.031	0.002	1.2	
		2	BB1-415V	0.415	1.0000	0.000	2.500	0.000	-0.031	0.044	1.2	
T6	1	1	BB5-11kV	11.000	1.0000	0.000	1.500	1.000	0.908	0.074	90.1	
		2	BB2-415V	0.433	1.0434	0.000	1.500	-1.000	-0.750	1.876	83.3	
T7	1	1	BB6-11kV	11.000	1.0000	0.000	2.000	0.001	0.001	0.000	0.1	
		2	BB3-415V	0.415	1.0000	0.000	2.000	-0.001	-0.001	0.002	0.1	
T8	1	1	BB7-11kV	11.000	1.0000	0.000	2.500	0.639	0.489	0.044	32.2	
		2	BB4-415V	0.415	1.0000	0.000	2.500	-0.600	-0.450	1.166	30.0	
T9	1	1	BB8-11kV	11.000	1.0000	0.000	2.000	0.001	0.001	0.000	0.1	
		2	BB5-415V	0.415	1.0000	0.000	2.000	-0.001	-0.001	0.002	0.1	
T10	1	1	BB10-11kV	11.000	1.0000	0.000	2.500	0.640	0.490	0.044	32.2	
		2	BB6-415V	0.415	1.0000	0.000	2.500	-0.600	-0.450	1.169	30.0	
T11	1	1	BB11-11kV	- WINDING DISCONNECTED								
		2	BB7-415V	- WINDING DISCONNECTED								
T12	1	1	BB12-11kV	11.000	1.0000	0.000	2.500	0.101	0.048	0.006	4.5	
		2	BB8-415V	0.415	1.0000	0.000	2.500	-0.100	-0.047	0.155	4.4	

Network Name : CASE2  
Data State Name : BB11-11kV OPEN

-----  
INDUCTION MACHINE VALUES

Busbar Identifier	Machine Identifier	No.Of Units	Slip %	Terminal Voltage kV	Machine MW	Input MVAr	Current kA	O/L Flag
BB1-415V	IM	1	0.00	0.398	0.000	0.031	0.044	
BB8-415V	IM2	1	0.74	0.412	0.100	0.047	0.155	
BB10-415V	IM3	1	0.19	0.354	0.100	0.127	0.263	

-----  
SYNCHRONOUS MACHINE VALUES

Busbar Identifier	Machine Identifier	No.Of Units	Terminal Voltage kV	Power MW	Output MVAr	Current kA	O/L Flag
BB 132kV	TNB A	1	132.000	1.458	1.207	0.008	
BB2 132kV	TNB B	1	132.000	3.733	4.058	0.024	
BB12-11kV	SG1	1	11.000	0.101	0.048	0.006	

-----  
SHUNT VALUES

Busbar Identifier	Shunt Identifier	Shunt MW	Load MVAR	Current kA	O/L Flag
BB2-415V	Load1	1.000	0.750	1.876	
BB3-415V	Load2	0.001	0.001	0.002	
BB4-415V	Load3	0.600	0.450	1.166	
BB5-415V	load 4	0.001	0.001	0.002	
BB6-415V	Load5	0.600	0.450	1.169	
BB7-415V	Load6	SHUNT DISCONNECTED			
BB9-415V	load7	0.500	0.375	1.035	
BB9-11kV		1.000	0.750	0.076	
BB11-415V	load8	0.900	0.675	1.865	
BB12-415V	load9	0.400	0.300	0.819	

Network Name : CASE2  
Data State Name : BB11-11kV OPEN

-----  
BUS SECTION VALUES

First Busbar	Second Busbar	MW	MVAr	kA
BB3-11kV	BB4-11kV	0.088	0.055	0.006
BB4-11kV	BB5-11kV	0.088	0.025	0.005
BB5-11kV	BB6-11kV	-0.183	-0.338	0.021
BB6-11kV	BB7-11kV	-0.184	-0.339	0.021
BB7-11kV	BB8-11kV	-0.823	-0.828	0.064
BB2 132kV	BB3 132kV	2.909	3.163	0.019
BB10-11kV	BB11-11kV	0.000	0.000	0.000
BB11-11kV	BB12-11kV	0.000	0.000	0.000
BB13-11kV	BB14-11kV	-0.500	-0.408	0.039
BB14-11kV	BB15-11kV	-0.602	-0.537	0.049

Network Name : CASE3  
 Data State Name : BB11-11kV & BB13-11kVOPEN

-----  
**SYSTEM STATISTICS**

Study Base MVA	=	100.000
Study Base Frequency (Hz)	=	50.000
Number of Busbars	=	30
Number of Shunts	=	10
Number of Lines	=	4
Number of Cables	=	0
Number of Transformers	=	15
Number of Tap Changers	=	0
Number of Synchronous Machines	=	3
Number of Induction Machines	=	3
Number of Wind Turbine Generators	=	0
Number of Bus Sections	=	10
Number of Series Elements	=	0

-----  
**STUDY PARAMETERS**

Load Power Multiplier	=	1.000000
Load Reactive Multiplier	=	1.000000
Convergence Tolerance	=	0.000005
Convergence Control	=	Method 2
Maximum Iterations	=	25
Overload Flag Level	=	100.0% Of Rating
Automatic Tap Changers	=	OFF

-----  
**BUSBAR DATA**

Busbar Identifier	Nominal kV	Three Phase Fault MVA	Fault kA	Single Phase Fault MVA	Fault kA	Transf. Shift Angle (deg.)	Nominal Bus Freq. (Hz)
BB 132kV	132.000	1500.0	6.561	2000.0	8.748	0.0	50.0
BB1-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB3-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB4-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB5-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB6-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB7-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB8-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB9-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB2-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB2 132kV	132.000	1500.0	6.561	2000.0	8.748	0.0	50.0
BB3 132kV	132.000	1500.0	6.561	2000.0	8.748	0.0	50.0
BB10-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB11-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB12-11kV	11.000	500.0	26.243	700.0	36.740	0.0	50.0
BB15-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB14-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB13-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB1-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB2-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB3-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB4-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB5-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0

Network Name : CASE3  
 Data State Name : BB11-11kV & BB13-11KVOPEN

**BUSBAR DATA**

Busbar Identifier	Nominal kv	Three Phase Fault MVA	kA	Single Phase Fault MVA	kA	Transf. Shift Angle (deg.)	Nominal Bus Freq. (Hz)
BB6-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB7-415V	0.415	31.0	43.127	45.0	62.604	0.0	50.0 NOT IN USE
BB8-415V	0.415	31.0	43.127	45.0	62.604	30.0	50.0
BB9-415V	0.415	31.0	43.127	45.0	62.604	0.0	50.0 NOT IN USE
BB10-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB11-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB12-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0

**LINE DATA**

First Busbar	Second Busbar	Line Identifier	No.Of Ccts	Line Length	Library Key	Rating (kA)	Positive R(pu)	Sequence X(pu))	Zero Sequence B(pu)	Sequence R(pu)	X(pu)	B(pu)	Equivalent Pi Model
BB3-11kV	BB10-11kV	L1	1	2.00	Line1	0.459	0.16694	0.12793	0.00001	1.98347	0.50909	0.00000	
BB9-11kV	BB15-11kV	L2	1	1.00	Line1	7.000	0.00826	0.00701	0.00002	0.00826	0.00701	0.00002	
BB1-11kV	BB3-11kV	L3	1	1.00	Line1	7.000	0.00826	0.00701	0.00002	0.00826	0.00701	0.00002	
BB2-11kV	BB5-11kV	L4	1	1.00	Line1	7.000	0.00826	0.00701	0.00002	0.00826	0.00701	0.00002	

**TRANSFORMER DATA**

System Busbar	Winding No.	Rating (MVA)	Winding Type	Angle (deg.)	Pos/Neg. R(pu)	Sequence X(pu)	Zero Sequence R(pu)	Sequence X(pu)	Neutral R(pu)	Earth X(pu)	Voltage Ratio	Off-Nom Tap (%)
DATA for Transformer with ID. T5												
BB4-11kV	1	2.500	D	30.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
BB1-415V	2	2.500	YN	0.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
DATA for Transformer with ID. T6												
BB5-11kV	1	1.500	D	30.00	0.0000	4.0000	0.1603	1.6033	0.0000	0.0000	1.0000	0.00
BB2-415V	2	1.500	YN	0.00	0.0000	4.0000	0.3333	1.6667	0.0000	0.0000	1.0434	0.00
DATA for Transformer with ID. T7												
BB6-11kV	1	2.000	D	30.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00
BB3-415V	2	2.000	YN	0.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00

Network Name : CASE3  
 Data State Name : BB11-11kV & BB13-11kVOPEN

-----  
**TRANSFORMER DATA**

System Busbar	Winding No.	Rating (MVA)	Winding Type	Angle (deg.)	Pos/Neg. R(pu)	Sequence X(pu)	Zero Sequence R(pu)	Sequence X(pu)	Neutral R(pu)	Earth X(pu)	Voltage Ratio	Off-Nom Tap (%)
<b>DATA for Transformer with ID. T8</b>												
BB7-11kV	1	2.500	D	30.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
BB4-415V	2	2.500	YN	0.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T9</b>												
BB8-11kV	1	2.000	D	30.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00
BB5-415V	2	2.000	YN	0.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T10</b>												
BB10-11kV	1	2.500	D	30.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
BB6-415V	2	2.500	YN	0.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T11</b>												
BB11-11kV	1	1.500	D	30.00	0.0000	4.0000	0.1603	1.6033	0.0000	0.0000	1.0000	0.00 OPEN AT SYSTEM BUS
BB7-415V	2	1.500	YN	0.00	0.0000	4.0000	0.3333	1.6667	0.0000	0.0000	1.0434	0.00
<b>DATA for Transformer with ID. T12</b>												
BB12-11kV	1	2.500	D	30.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
BB8-415V	2	2.500	YN	0.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T13</b>												
BB13-11kV	1	2.000	D	30.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00 OPEN AT SYSTEM BUS
BB9-415V	2	2.000	YN	0.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T14</b>												
BB14-11kV	1	2.500	D	30.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
BB10-415V	2	2.500	YN	0.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T15</b>												
BB15-11kV	1	2.500	D	30.00	0.0800	0.8000	0.0600	0.6000	0.0000	0.0000	1.0000	0.00
BB11-415V	2	2.500	YN	0.00	0.1600	1.9240	0.0800	1.4000	0.0000	0.0000	1.0000	0.00
BB12-415V	3	2.500	YN	0.00	0.0800	1.9240	0.0640	0.1400	0.0000	0.0000	1.0000	0.00

Network Name : CASE3  
 Data State Name : BB11-11kV & BB13-11kVOPEN

-----  
**TRANSFORMER DATA**

System Busbar	Winding No.	Rating (MVA)	Winding Type	Angle (deg.)	Pos/Neg. R(pu)	Sequence X(pu)	Zero Sequence R(pu)	Sequence X(pu)	Neutral R(pu)	Earth X(pu)	Voltage Ratio	Off-Nom Tap (%)
DATA for Transformer with ID. T1												
BB 132kV	1	4.000	D	30.00	0.0000	3.3750	0.0591	0.5907	0.0000	0.0000	1.0000	0.00
BB1-11kV	2	4.000	YN	0.00	0.0000	3.3750	0.0591	0.5907	0.0000	0.0000	1.0000	0.00
DATA for Transformer with ID. T2												
BB 132kV	1	4.000	D	30.00	0.0000	3.3750	0.0591	0.5907	0.0000	0.0000	1.0000	0.00
BB2-11kV	2	4.000	YN	0.00	0.0000	3.3750	0.0591	0.5907	0.0000	0.0000	1.0000	0.00
DATA for Transformer with ID. T3												
BB2 132kV	1	6.000	D	30.00	0.0000	2.2500	0.0540	0.5390	0.0000	0.0000	1.0000	0.00
BB8-11kV	2	6.000	YN	0.00	0.0000	2.2500	0.0540	0.5390	0.0000	0.0000	1.0000	0.00
DATA for Transformer with ID. T4												
BB3 132kV	1	6.000	D	30.00	0.0000	2.2500	0.0540	0.5390	0.0000	0.0000	1.0000	0.00
BB9-11kV	2	6.000	YN	0.00	0.0000	2.2500	0.0540	0.5390	0.0000	0.0000	1.0000	0.00

-----  
**INDUCTION MACHINE DATA**

Busbar Identifier	Motor Identifier	No.Of Library Units	Library Key	Motor MVA	Ratings MW	Input kV	Slip (%)	Stator R(pu)	Magnet. X(pu)	Standstill X(pu)	Rotor R(pu)	Running X(pu)
BB1-415V	IM	1	M003	0.196	0.196	0.415	0.000	0.0000	0.0185	0.0918	5.8000	0.0215 0.1060 0.0134 0.1910
BB8-415V	IM2	1	M003	0.196	0.196	0.415	0.100	0.6837	0.0185	0.0918	5.8000	0.0215 0.1060 0.0134 0.1910
BB10-415V	IM3	1	M002	1.000	1.000	0.415	0.100	0.1340	0.0185	0.0918	5.8000	0.0215 0.1060 0.0134 0.1910

Network Name : CASE3  
Data State Name : BB11-11kV & BB13-11KVOPEN

-----  
BUS SECTION DATA  
-----

First Busbar	Second Busbar	Status
BB3-11kV	BB4-11kV	Closed
BB4-11kV	BB5-11kV	Closed
BB5-11kV	BB6-11kV	Closed
BB6-11kV	BB7-11kV	Closed
BB7-11kV	BB8-11kV	Closed
BB2 132kV	BB3 132kV	Closed
BB10-11kV	BB11-11kV	Closed
BB11-11kV	BB12-11kV	Open
BB13-11kV	BB14-11kV	Closed
BB14-11kV	BB15-11kV	Closed

-----

Network Name : CASE3  
Data State Name : BB11-11kV & BB13-11kVOPEN

AT STUDY END - No of iterations = 4 Convergence = 0.1274E-05  
Voltage Range from 0.868pu at BB11-415V to 1.000pu at BB12-11kV

### AC BUSBAR VALUES

Network Name : CASE3

Data State Name : BB11-11kV & BB13-11KVOPEN

BUSBAR TOTALS	4.791	4.610	0.200	0.213	4.502	3.377
TOTAL BUS LOAD	4.702	3.589				
SYSTEM LOSSES	0.089	1.021				

-----  
**LINE VALUES**

First Busbar	Second Busbar	Branch Identifier	No.Of Ccts	Rating kA	First MW	End MVar	Flow kA	Second MW	End MVar	Flow kA	Loading (%)	O/L FLAG
BB3-11kV	BB10-11kV	L1	1	0.459	0.641	0.490	0.044	-0.640	-0.490	0.044	9.6	
BB9-11kV	BB15-11kV	L2	1	7.000	1.408	1.177	0.108	-1.408	-1.178	0.108	1.5	
BB1-11kV	BB3-11kV	L3	1	7.000	0.715	0.544	0.049	-0.715	-0.546	0.049	0.7	
BB2-11kV	BB5-11kV	L4	1	7.000	0.715	0.544	0.049	-0.715	-0.546	0.049	0.7	

-----  
**TRANSFORMER VALUES**

Transformer Identifier	No.Of Units	Winding No.	Connected Busbar	Winding kV	Voltage Ratio	Off Tap %	Nominal Tap %	Rating MVA	Flow From Busbar MW	Current kA	Percent O/L Loading	O/L Flag
T5	1	1	BB4-11kV	11.000	1.0000	0.000	2.500	0.000	0.031	0.002	1.2	
		2	BB1-415V	0.415	1.0000	0.000	2.500	0.000	-0.031	0.044	1.2	
T6	1	1	BB5-11kV	11.000	1.0000	0.000	1.500	1.000	0.908	0.074	90.1	
		2	BB2-415V	0.433	1.0434	0.000	1.500	-1.000	-0.750	1.876	83.3	
T7	1	1	BB6-11kV	11.000	1.0000	0.000	2.000	0.001	0.001	0.000	0.1	
		2	BB3-415V	0.415	1.0000	0.000	2.000	-0.001	-0.001	0.002	0.1	
T8	1	1	BB7-11kV	11.000	1.0000	0.000	2.500	0.639	0.489	0.044	32.2	
		2	BB4-415V	0.415	1.0000	0.000	2.500	-0.600	-0.450	1.166	30.0	
T9	1	1	BB8-11kV	11.000	1.0000	0.000	2.000	0.001	0.001	0.000	0.1	
		2	BB5-415V	0.415	1.0000	0.000	2.000	-0.001	-0.001	0.002	0.1	
T10	1	1	BB10-11kV	11.000	1.0000	0.000	2.500	0.640	0.490	0.044	32.2	
		2	BB6-415V	0.415	1.0000	0.000	2.500	-0.600	-0.450	1.169	30.0	
T11	1	1	BB11-11kV	- WINDING DISCONNECTED								
		2	BB7-415V	- WINDING DISCONNECTED								
T12	1	1	BB12-11kV	11.000	1.0000	0.000	2.500	0.101	0.048	0.006	4.5	
		2	BB8-415V	0.415	1.0000	0.000	2.500	-0.100	-0.047	0.155	4.4	

Network Name : CASE3  
 Data State Name : BB11-11kV & BB13-11kVOPEN

-----  
**TRANSFORMER VALUES**

Transformer Identifier	No. Of Units	Winding No.	Connected Busbar	Winding kV	Voltage Ratio	Off Nominal Tap %	Rating MVA	Flow MW	From Busbar MVar	Current kA	Percent O/L Loading Flag
<hr/>											
T13	1	1	BB13-11kV	- WINDING DISCONNECTED							
		2	BB9-415V	- WINDING DISCONNECTED							
<hr/>											
T14	1	1	BB14-11kV	11.000	1.0000	0.000	2.500	0.102	0.137	0.010	6.8
		2	BB10-415V	0.415	1.0000	0.000	2.500	-0.100	-0.135	0.265	6.7
<hr/>											
T15	1	1	BB15-11kV	11.000	1.0000	0.000	2.500	1.306	1.041	0.098	66.8
		2	BB11-415V	0.415	1.0000	0.000	2.500	-0.900	-0.675	1.802	45.0
		3	BB12-415V	0.415	1.0000	0.000	2.500	-0.400	-0.300	0.792	20.0
<hr/>											
T1	1	1	BB 132kV	132.000	1.0000	0.000	4.000	0.715	0.603	0.004	23.4
		2	BB1-11kV	11.000	1.0000	0.000	4.000	-0.715	-0.544	0.049	22.5
<hr/>											
T2	1	1	BB 132kV	132.000	1.0000	0.000	4.000	0.715	0.603	0.004	23.4
		2	BB2-11kV	11.000	1.0000	0.000	4.000	-0.715	-0.544	0.049	22.5
<hr/>											
T3	1	1	BB2 132kV	132.000	1.0000	0.000	6.000	0.852	0.897	0.005	20.6
		2	BB8-11kV	11.000	1.0000	0.000	6.000	-0.852	-0.828	0.065	19.8
<hr/>											
T4	1	1	BB3 132kV	132.000	1.0000	0.000	6.000	2.408	2.460	0.015	57.4
		2	BB9-11kV	11.000	1.0000	0.000	6.000	-2.408	-1.927	0.181	51.4

-----  
**BRANCH LOSS SUMMARY**

	(MW)	(MVar)
SERIES LOSSES	0.089	1.028
SHUNT LOSSES	0.000	-0.007
<hr/>		
TOTAL LOSSES	0.089	1.021
<hr/>		

Network Name : CASE3  
Data State Name : BB11-11kV & BB13-11kVOPEN

-----  
INDUCTION MACHINE VALUES

Busbar Identifier	Machine Identifier	No.Of Units	Slip %	Terminal Voltage kV	Machine MW	Input MVAr	Current kA	O/L Flag
BB1-415V	IM	1	0.00	0.398	0.000	0.031	0.044	
BB8-415V	IM2	1	0.74	0.412	0.100	0.047	0.155	
BB10-415V	IM3	1	0.18	0.366	0.100	0.135	0.265	

-----  
SYNCHRONOUS MACHINE VALUES

Busbar Identifier	Machine Identifier	No.Of Units	Terminal Voltage kV	Power MW	Output MVAr	Current kA	O/L Flag
BB 132kV	TNB A	1	132.000	1.430	1.206	0.008	
BB2 132kV	TNB B	1	132.000	3.260	3.356	0.020	
BB12-11kV	SG1	1	11.000	0.101	0.048	0.006	

-----  
SHUNT VALUES

Busbar Identifier	Shunt Identifier	Shunt MW	Load MVAr	Current kA	O/L Flag
BB2-415V	Load1	1.000	0.750	1.876	
BB3-415V	Load2	0.001	0.001	0.002	
BB4-415V	Load3	0.600	0.450	1.166	
BB5-415V	load 4	0.001	0.001	0.002	
BB6-415V	Load5	0.600	0.450	1.169	
BB7-415V	Load6	SHUNT DISCONNECTED			
BB9-415V	load7	SHUNT DISCONNECTED			
BB9-11kV		1.000	0.750	0.073	
BB11-415V	load8	0.900	0.675	1.802	
BB12-415V	load9	0.400	0.300	0.792	

Network Name : CASE3  
Data State Name : BB11-11kV & BB13-11KVOPEN

BUS SECTION VALUES

First Busbar	Second Busbar	MW	MVar	kA
BB3-11kV	BB4-11kV	0.074	0.056	0.005
BB4-11kV	BB5-11kV	0.074	0.025	0.004
BB5-11kV	BB6-11kV	-0.211	-0.337	0.022
BB6-11kV	BB7-11kV	-0.212	-0.338	0.022
BB7-11kV	BB8-11kV	-0.851	-0.827	0.065
BB2 132kV	BB3 132kV	2.408	2.460	0.015
BB10-11kV	BB11-11kV	0.000	0.000	0.000
BB11-11kV	BB12-11kV	0.000	0.000	0.000
BB13-11kV	BB14-11kV	0.000	0.000	0.000
BB14-11kV	BB15-11kV	-0.102	-0.137	0.010

Network Name : CASE4  
 Data State Name : BB11-11kV & BB13-11kV BB7OPEN

-----  
**SYSTEM STATISTICS**

Study Base MVA	= 100.000
Study Base Frequency (Hz)	= 50.000
Number of Busbars	= 30
Number of Shunts	= 10
Number of Lines	= 4
Number of Cables	= 0
Number of Transformers	= 15
Number of Tap Changers	= 0
Number of Synchronous Machines	= 3
Number of Induction Machines	= 3
Number of Wind Turbine Generators	= 0
Number of Bus Sections	= 10
Number of Series Elements	= 0

-----  
**STUDY PARAMETERS**

Load Power Multiplier	= 1.000000
Load Reactive Multiplier	= 1.000000
Convergence Tolerance	= 0.000005
Convergence Control	= Method 2
Maximum Iterations	= 25
Overload Flag Level	= 100.0% Of Rating
Automatic Tap Changers	OFF

-----  
**BUSBAR DATA**

Busbar Identifier	Nominal kv	Three Phase Fault MVA	Three Phase Fault kA	Single Phase Fault MVA	Single Phase Fault kA	Transf. Shift Angle (deg.)	Nominal Bus Freq. (Hz)
BB 132kV	132.000	1500.0	6.561	2000.0	8.748	0.0	50.0
BB1-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB3-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB4-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB5-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB6-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB7-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB8-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB9-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB2-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB2 132kV	132.000	1500.0	6.561	2000.0	8.748	0.0	50.0
BB3 132kV	132.000	1500.0	6.561	2000.0	8.748	0.0	50.0
BB10-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB11-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB12-11kV	11.000	500.0	26.243	700.0	36.740	0.0	50.0
BB15-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB14-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB13-11kV	11.000	500.0	26.243	700.0	36.740	30.0	50.0
BB1-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB2-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB3-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB4-415V	0.415	31.0	43.127	45.0	62.604	0.0	50.0 NOT IN USE
BB5-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0

Network Name : CASE4  
 Data State Name : BB11-11kV & BB13-11kV BB7OPEN

BUSBAR DATA

Busbar Identifier	Nominal kV	Three Phase Fault MVA	kA	Single Phase Fault MVA	kA	Transf. Shift Angle (deg.)	Nominal Bus Freq. (Hz)
BB6-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB7-415V	0.415	31.0	43.127	45.0	62.604	0.0	50.0 NOT IN USE
BB8-415V	0.415	31.0	43.127	45.0	62.604	30.0	50.0
BB9-415V	0.415	31.0	43.127	45.0	62.604	0.0	50.0 NOT IN USE
BB10-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB11-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0
BB12-415V	0.415	31.0	43.127	45.0	62.604	60.0	50.0

LINE DATA

First Busbar	Second Busbar	Line Identifier	No.Of Ccts	Line Length	Library Key	Rating (kA)	Positive R(pu)	Sequence X(pu))	Zero Sequence B(pu)	Sequence R(pu)	X(pu)	B(pu)	Equivalent Pi Model
BB3-11kV	BB10-11kV	L1	1	2.00	Line1	0.459	0.16694	0.12793	0.00001	1.98347	0.50909	0.00000	
BB9-11kV	BB15-11kV	L2	1	1.00	Line1	7.000	0.00826	0.00701	0.00002	0.00826	0.00701	0.00002	
BB1-11kV	BB3-11kV	L3	1	1.00	Line1	7.000	0.00826	0.00701	0.00002	0.00826	0.00701	0.00002	
BB2-11kV	BB5-11kV	L4	1	1.00	Line1	7.000	0.00826	0.00701	0.00002	0.00826	0.00701	0.00002	

TRANSFORMER DATA

System Busbar	Winding No.	Rating (MVA)	Winding Type	Angle (deg.)	Pos/Neg. R(pu)	Sequence X(pu)	Zero Sequence R(pu)	Sequence X(pu)	Neutral R(pu)	Earth X(pu)	Voltage Ratio	Off-Nom Tap (%)
---------------	-------------	--------------	--------------	--------------	----------------	----------------	---------------------	----------------	---------------	-------------	---------------	-----------------

DATA for Transformer with ID. T5                  No. of units 1 using library key T004

BB4-11kV	1	2.500	D	30.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
BB1-415V	2	2.500	YN	0.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00

DATA for Transformer with ID. T6                  No. of units 1 using library key T006

BB5-11kV	1	1.500	D	30.00	0.0000	4.0000	0.1603	1.6033	0.0000	0.0000	1.0000	0.00
BB2-415V	2	1.500	YN	0.00	0.0000	4.0000	0.3333	1.6667	0.0000	0.0000	1.0434	0.00

DATA for Transformer with ID. T7                  No. of units 1 using library key T003

BB6-11kV	1	2.000	D	30.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00
BB3-415V	2	2.000	YN	0.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00

Network Name : CASE4  
 Data State Name : BB11-11kV & BB13-11kV BB7OPEN

-----  
**TRANSFORMER DATA**

System Busbar	Winding No.	Rating (MVA)	Winding Type	Angle (deg.)	Pos/Neg. R(pu)	Sequence X(pu)	Zero Sequence R(pu)	Sequence X(pu)	Neutral R(pu)	Earth X(pu)	Voltage Ratio	Off-Nom Tap (%)
<b>DATA for Transformer with ID. T8</b>												
BB7-11kV	1	2.500	D	30.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00 OPEN AT SYSTEM BUS
BB4-415V	2	2.500	YN	0.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T9</b>												
BB8-11kV	1	2.000	D	30.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00
BB5-415V	2	2.000	YN	0.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T10</b>												
BB10-11kV	1	2.500	D	30.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
BB6-415V	2	2.500	YN	0.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T11</b>												
BB11-11kV	1	1.500	D	30.00	0.0000	4.0000	0.1603	1.6033	0.0000	0.0000	1.0000	0.00 OPEN AT SYSTEM BUS
BB7-415V	2	1.500	YN	0.00	0.0000	4.0000	0.3333	1.6667	0.0000	0.0000	1.0434	0.00
<b>DATA for Transformer with ID. T12</b>												
BB12-11kV	1	2.500	D	30.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
BB8-415V	2	2.500	YN	0.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T13</b>												
BB13-11kV	1	2.000	D	30.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00 OPEN AT SYSTEM BUS
BB9-415V	2	2.000	YN	0.00	0.0000	3.0000	0.1176	1.1755	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T14</b>												
BB14-11kV	1	2.500	D	30.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
BB10-415V	2	2.500	YN	0.00	2.8000	2.8000	0.0938	0.9384	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T15</b>												
BB15-11kV	1	2.500	D	30.00	0.0800	0.8000	0.0600	0.6000	0.0000	0.0000	1.0000	0.00
BB11-415V	2	2.500	YN	0.00	0.1600	1.9240	0.0800	1.4000	0.0000	0.0000	1.0000	0.00
BB12-415V	3	2.500	YN	0.00	0.0800	1.9240	0.0640	0.1400	0.0000	0.0000	1.0000	0.00

Network Name : CASE4  
 Data State Name : BB11-11kV & BB13-11kV BB7OPEN

-----  
**TRANSFORMER DATA**

System Busbar	Winding No.	Rating (MVA)	Winding Type	Angle (deg.)	Pos/Neg. R(pu)	Sequence X(pu)	Zero Sequence R(pu)	Sequence X(pu)	Neutral R(pu)	Earth X(pu)	Voltage Ratio	Off-Nom Tap (%)
<b>DATA for Transformer with ID. T1</b>												
BB 132kV	1	4.000	D	30.00	0.0000	3.3750	0.0591	0.5907	0.0000	0.0000	1.0000	0.00
BB1-11kV	2	4.000	YN	0.00	0.0000	3.3750	0.0591	0.5907	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T2</b>												
BB 132kV	1	4.000	D	30.00	0.0000	3.3750	0.0591	0.5907	0.0000	0.0000	1.0000	0.00
BB2-11kV	2	4.000	YN	0.00	0.0000	3.3750	0.0591	0.5907	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T3</b>												
BB2 132kV	1	6.000	D	30.00	0.0000	2.2500	0.0540	0.5390	0.0000	0.0000	1.0000	0.00
BB8-11kV	2	6.000	YN	0.00	0.0000	2.2500	0.0540	0.5390	0.0000	0.0000	1.0000	0.00
<b>DATA for Transformer with ID. T4</b>												
BB3 132kV	1	6.000	D	30.00	0.0000	2.2500	0.0540	0.5390	0.0000	0.0000	1.0000	0.00
BB9-11kV	2	6.000	YN	0.00	0.0000	2.2500	0.0540	0.5390	0.0000	0.0000	1.0000	0.00

-----  
**INDUCTION MACHINE DATA**

Busbar Identifier	Motor Identifier	No.Of Library Units Key	Motor MVA	Ratings MW	Input kv	Slip MW	Stator R(pu)	Magnet. X(pu)	Standstill X(pu)	Rotor R(pu)	Running X(pu)
BB1-415V	IM	1 M003	0.196	0.196	0.415	0.000	0.0000	0.0185	0.0918	5.8000	0.0215 0.1060
BB8-415V	IM2	1 M003	0.196	0.196	0.415	0.100	0.6837	0.0185	0.0918	5.8000	0.0215 0.1060
BB10-415V	IM3	1 M002	1.000	1.000	0.415	0.100	0.1340	0.0185	0.0918	5.8000	0.0215 0.1060

Network Name : CASE4  
 Data State Name : BB11-11kV & BB13-11kV BB7OPEN

-----  
**INFINITE GENERATOR DATA**

Busbar Identifier	Machine Identifier	Machine MVA	Ratings MW	kV	Assigned V(pu)	Pos. R(pu)	Sequence X(pu)	Neg. R(pu)	Sequence X(pu)	Zero R(pu)	Sequence X(pu)
BB 132kV	TNB A	150.00	14.93	132.00	1.000	0.0995	0.9950	0.0995	0.9950	0.0995	0.9950
BB2 132kV	TNB B	150.00	14.93	132.00	1.000	0.0995	0.9950	0.0995	0.9950	0.0995	0.9950

-----  
**SYNCHRONOUS MACHINE DATA**

Busbar Identifier	Machine Identifier	Type	No.Of Units	Library Key	Generator MVA BASE	Ratings MW	kV	Assigned V(pu)	MW	MVAR	Pos. R(pu)	Sequence X(pu)	Neg. R(pu)	Sequence X(pu)	Zero R(pu)	Sequence X(pu)
BB12-11kV	SG1	SLACK	1	GMIN	50.000	50.000	11.000	1.000	0.000	0.000	0.0120	0.2770	0.0200	0.1840	0.0150	0.0800

Neutral earthing  
 0.0000 0.0000 0.0000 0.0000 0.0000 0.0000

-----  
**SHUNT DATA**

Busbar Identifier	Shunt Identifier	No.Of Units	Type	Library Key	Rating MVA	Positive/Negative Sequence	Data Values	Zero Sequence
BB2-415V	Load1	1	MW/pf	Ld1		1.000 MW	0.800 pf	
BB3-415V	Load2	1	G/B pu Base	SampleG/Bpu1	1.00	0.008 G pu	-0.006 B pu	0.008 G pu
BB4-415V	Load3	1	kW/pf	samplekW/pf		600.000 kW	0.800 pf	
BB5-415V	load 4	1	R/X Ohm	sampleR/X	1.50	100.000 R Ohm	75.000 X Ohm	100.000 R Ohm
BB6-415V	Load5	1	kW/pf	samplekW/pf		600.000 kW	0.800 pf	
BB7-415V	Load6	1	MW/pf	Ld2		0.900 MW	0.800 pf	
BB9-415V	load7	1	MW/pf	Ld1		0.500 MW	0.800 pf	
BB9-11kV		1	MW/MVAR	Load1		1.000 MW	0.750 MVar	
BB11-415V	load8	1	MW/pf	Ld2		0.900 MW	0.800 pf	
BB12-415V	load9	1	MW/pf	Ld2		0.400 MW	0.800 pf	

Network Name : CASE4  
Data State Name : BB11-11kV & BB13-11kV BB7OPEN

-----  
BUS SECTION DATA

First Busbar	Second Busbar	Status
BB3-11kV	BB4-11kV	Closed
BB4-11kV	BB5-11kV	Closed
BB5-11kV	BB6-11kV	Closed
BB6-11kV	BB7-11kV	Closed
BB7-11kV	BB8-11kV	Closed
BB2 132kV	BB3 132kV	Closed
BB10-11kV	BB11-11kV	Closed
BB11-11kV	BB12-11kV	Open
BB13-11kV	BB14-11kV	Closed
BB14-11kV	BB15-11kV	Closed

-----

Network Name : CASE4  
Data State Name : BB11-11kV & BB13-11kV BB7OPEN

AT STUDY END - No of iterations = 4 Convergence = 0.1289E-05  
Voltage Range from 0.868pu at BB11-415V to 1.000pu at BB 132kV

#### AC BUSBAR VALUES

Network Name : CASE4

Data State Name : BB11-11kV & BB13-11kV BB7OPEN

BUSBAR TOTALS	4.151	4.027	0.200	0.213	3.902	2.927
TOTAL BUS LOAD	4.102	3.140				
SYSTEM LOSSES	0.049	0.887				

-----  
**LINE VALUES**

First Busbar	Second Busbar	Branch Identifier	No.Of Ccts	Rating kA	First MW	End MVar	Flow kA	Second MW	End MVar	Flow kA	Loading (%)	O/L FLAG
BB3-11kV	BB10-11kV	L1	1	0.459	0.640	0.489	0.044	-0.639	-0.489	0.044	9.5	
BB9-11kV	BB15-11kV	L2	1	7.000	1.408	1.177	0.108	-1.408	-1.178	0.108	1.5	
BB1-11kV	BB3-11kV	L3	1	7.000	0.536	0.404	0.036	-0.536	-0.406	0.036	0.5	
BB2-11kV	BB5-11kV	L4	1	7.000	0.536	0.404	0.036	-0.536	-0.406	0.036	0.5	

-----  
**TRANSFORMER VALUES**

Transformer Identifier	No.Of Units	Winding No.	Connected Busbar	Winding kV	Voltage Ratio	Off Tap %	Nominal	Rating MVA	Flow From Busbar	Current kA	Percent O/L Loading	Flag
T5	1	1	BB4-11kV	11.000	1.0000	0.000	2.500	0.000	0.031	0.002	1.3	
		2	BB1-415V	0.415	1.0000	0.000	2.500	0.000	-0.031	0.045	1.3	
T6	1	1	BB5-11kV	11.000	1.0000	0.000	1.500	1.000	0.904	0.073	89.9	
		2	BB2-415V	0.433	1.0434	0.000	1.500	-1.000	-0.750	1.851	83.3	
T7	1	1	BB6-11kV	11.000	1.0000	0.000	2.000	0.001	0.001	0.000	0.1	
		2	BB3-415V	0.415	1.0000	0.000	2.000	-0.001	-0.001	0.002	0.1	
T8	1	1	BB7-11kV	- WINDING DISCONNECTED			- WINDING DISCONNECTED					
		2	BB4-415V	- WINDING DISCONNECTED			- WINDING DISCONNECTED					
T9	1	1	BB8-11kV	11.000	1.0000	0.000	2.000	0.001	0.001	0.000	0.1	
		2	BB5-415V	0.415	1.0000	0.000	2.000	-0.001	-0.001	0.002	0.1	
T10	1	1	BB10-11kV	11.000	1.0000	0.000	2.500	0.639	0.489	0.044	32.2	
		2	BB6-415V	0.415	1.0000	0.000	2.500	-0.600	-0.450	1.154	30.0	
T11	1	1	BB11-11kV	- WINDING DISCONNECTED			- WINDING DISCONNECTED					
		2	BB7-415V	- WINDING DISCONNECTED			- WINDING DISCONNECTED					
T12	1	1	BB12-11kV	11.000	1.0000	0.000	2.500	0.101	0.048	0.006	4.5	
		2	BB8-415V	0.415	1.0000	0.000	2.500	-0.100	-0.047	0.155	4.4	

Network Name : CASE4  
 Data State Name : BB11-11kV & BB13-11kV BB7OPEN

-----  
**TRANSFORMER VALUES**

Transformer Identifier	No.Of Units	Winding No.	Connected Busbar	Winding kV	Voltage Ratio	Off Nominal Tap %	Rating MVA	Flow MW	From Busbar MVar	Current kA	Percent O/L Loading	Flag
T13	1	1	BB13-11kV	- WINDING DISCONNECTED								
		2	BB9-415V	- WINDING DISCONNECTED								
T14	1	1	BB14-11kV	11.000	1.0000	0.000	2.500	0.102	0.137	0.010	6.8	
		2	BB10-415V	0.415	1.0000	0.000	2.500	-0.100	-0.135	0.265	6.7	
T15	1	1	BB15-11kV	11.000	1.0000	0.000	2.500	1.306	1.041	0.098	66.8	
		2	BB11-415V	0.415	1.0000	0.000	2.500	-0.900	-0.675	1.802	45.0	
		3	BB12-415V	0.415	1.0000	0.000	2.500	-0.400	-0.300	0.792	20.0	
T1	1	1	BB 132kV	132.000	1.0000	0.000	4.000	0.536	0.436	0.003	17.3	
		2	BB1-11kV	11.000	1.0000	0.000	4.000	-0.536	-0.404	0.036	16.8	
T2	1	1	BB 132kV	132.000	1.0000	0.000	4.000	0.536	0.436	0.003	17.3	
		2	BB2-11kV	11.000	1.0000	0.000	4.000	-0.536	-0.404	0.036	16.8	
T3	1	1	BB2 132kV	132.000	1.0000	0.000	6.000	0.570	0.648	0.004	14.4	
		2	BB8-11kV	11.000	1.0000	0.000	6.000	-0.570	-0.614	0.045	14.0	
T4	1	1	BB3 132kV	132.000	1.0000	0.000	6.000	2.408	2.460	0.015	57.4	
		2	BB9-11kV	11.000	1.0000	0.000	6.000	-2.408	-1.927	0.181	51.4	

-----  
**BRANCH LOSS SUMMARY**

	(MW)	(MVar)
SERIES LOSSES	0.049	0.894
SHUNT LOSSES	0.000	-0.007
TOTAL LOSSES	0.049	0.887
	=====	=====

Network Name : CASE4  
Data State Name : BB11-11kV & BB13-11kV BB7OPEN

-----  
INDUCTION MACHINE VALUES

Busbar Identifier	Machine Identifier	No.Of Units	Slip %	Terminal Voltage kV	Machine MW	Input MVAr	Current kA	O/L Flag
BB1-415V	IM	1	0.00	0.402	0.000	0.031	0.045	
BB8-415V	IM2	1	0.74	0.412	0.100	0.047	0.155	
BB10-415V	IM3	1	0.18	0.366	0.100	0.135	0.265	

-----  
SYNCHRONOUS MACHINE VALUES

Busbar Identifier	Machine Identifier	No.Of Units	Terminal Voltage kV	Power MW	Output MVAr	Current kA	O/L Flag
BB 132kV	TNB A	1	132.000	1.072	0.872	0.006	
BB2 132kV	TNB B	1	132.000	2.979	3.108	0.019	
BB12-11kV	SG1	1	11.000	0.101	0.048	0.006	

-----  
SHUNT VALUES

Busbar Identifier	Shunt Identifier	Shunt MW	Load MVA	Current kA	O/L Flag
BB2-415V	Load1	1.000	0.750	1.851	
BB3-415V	Load2	0.001	0.001	0.002	
BB4-415V	Load3	SHUNT DISCONNECTED			
BB5-415V	load 4	0.001	0.001	0.002	
BB6-415V	Load5	0.600	0.450	1.154	
BB7-415V	Load6	SHUNT DISCONNECTED			
BB9-415V	load7	SHUNT DISCONNECTED			
BB9-11kV		1.000	0.750	0.073	
BB11-415V	load8	0.900	0.675	1.802	
BB12-415V	load9	0.400	0.300	0.792	

Network Name : CASE4  
Data State Name : BB11-11kV & BB13-11kV BB7OPEN

-----  
BUS SECTION VALUES

First Busbar	Second Busbar	MW	MVar	kA
BB3-11kV	BB4-11kV	-0.104	-0.083	0.007
BB4-11kV	BB5-11kV	-0.104	-0.114	0.008
BB5-11kV	BB6-11kV	-0.568	-0.613	0.045
BB6-11kV	BB7-11kV	-0.569	-0.614	0.045
BB7-11kV	BB8-11kV	-0.569	-0.614	0.045
BB2 132kV	BB3 132kV	2.408	2.460	0.015
BB10-11kV	BB11-11kV	0.000	0.000	0.000
BB11-11kV	BB12-11kV	0.000	0.000	0.000
BB13-11kV	BB14-11kV	0.000	0.000	0.000
BB14-11kV	BB15-11kV	-0.102	-0.137	0.010